




**Customer: ELFA AB**  
56-126-84

**Transf. No. AA-58057**  
**Designed: 1995-03-24 / ts**



#### Classification

Protection against electrical shock:	Isolating Transformer
Protection index:	IP00
Protection against short-circuit and abnormal use:	Non-short-circuit proof
Time of operation:	Continuously
Intended use:	Incorporated
Ambient temperature / Material Classification:	Ta40/E

Assembling:	1 pc	Metal Washer	D = 90	mm
	2 pcs	Rubber Pads	D = 90	mm

Dimensions:	OD =	115	mm
	H =	65	mm

Terminations:	Prim:	Multistranded Wire Style 3266.	Awg 22	L = 200mm
	Sec:	Solid Copper insulated with tubes of Natvar.		L = 200mm

Label on the paper box.

	Toroid International AB		
	Transf.No.	AA-58057	
	ELFA P/N:	56-126-84	

Label on transformer.

	Toroid International AB			 	
	Transf.No.	AA-58057			
	Prim.	230V 48-60Hz ye-ye			
	Sec.	2x 50V	300 VA		gn-re/bn-bu
					Fuse: 3,15A





## EC/EEA Declaration of conformity

*Type of equipment:* **Isolating Transformer**

*Brand name:* **Toroid**

*Part no:* **AA-58057**

*Customer:* **ELFA AB** **56-126-84**

<i>Manufactures:</i>	Toroid International (Pvt) Ltd PO Box 15, Phase 2, FTZ Katunayake, Sri-Lanka	Toroid International AB Box 3 351 03 Växjö, Sweden
	Toroid India Pvt Ltd Technopark Campus Trivandrum 695 581 Kerala, India	<i>Manufacture's representative within EEA:</i> Toroid International AB Box 3 351 03 Växjö, Sweden

*As the manufacturer's authorised representative established within EEA, we declare that the product is in conformity with the provision of the EC directives: Low Voltage Directiven (LVD) 73/23/EEG, 93/68/EEG*

*The product fulfils the requirements according to the following harmonised standards:  
EN 61558-1, EN 60 950, EN 60 065 and IEC 601-1.*

*All transformers have been inspected and tested with approved result according to the following:*

1. Ocular inspection
2. No-load input current
3. No-load secondary voltage
4. Dielectric strength between primary an

*The product is to be regarded as a modular component to be used in an electric apparatus that in turn has to fulfil the EMC - directives.*

*The product itself does not need to be EMC approved for CE marking according to directive 89/336/EEG, 92/31/EEG and 93/68/EEG*

*Date:* 2003-05-07

---

*Thomas Svensson / Design engineer*