- 1-channel
- · DC version, positive polarity
- Working voltage 26.5 V at 10 μA
- Series resistance max. 342  $\Omega$  + 2 V
- Fuse rating 50 mA
- · DIN rail mounting
- · Current limiting


## **Function**

The Zener Barrier prevents the transfer of unacceptably high energy from the safe area into the hazardous area.

The zener diodes in the Zener Barrier are connected in the reverse direction. The breakdown voltage of the diodes is not exceeded in normal operation. If this voltage is exceeded, due to a fault in the safe area, the diodes start to conduct, causing the fuse to blow. The Zener Barrier has a positive polarity, i. e. the anodes of the zener diodes are grounded.

The connection to the field circuit is equipped with a current limiting.


## **Assembly**








## Connection





Zone 2

Div. 2

Refer to "General Notes Relating to Pepperl+Fuchs Product Information"

Release date 2014-11-0410:21 Date of issue 2015-02-16 071790\_eng.xml

General specifications		
Туре		DC version, positive polarity
Electrical specifications		20 10101011, postation potation
Nominal resistance		300 Ω
Series resistance		max. 342 Ω +2 V
Fuse rating		50 mA
Hazardous area connection		
Connection		terminals 1, 2
Current limit		45 mA
Safe area connection		
Connection		terminals 7, 8
Working voltage		max. 26.9 V , 26.5 V at 10 μA
Conformity		παλ. 20.3 γ , 20.3 γ αι 10 μΑ
Degree of protection		IEC 60529
Ambient conditions		IEC 00329
Ambient temperature		-20 60 °C (-4 140 °F)
Storage temperature		·
Relative humidity		-25 70 °C (-13 158 °F)
Mechanical specifications		max. 75 %, without moisture condensation
•		IDOO
Degree of protection		IP20
Connection		self-opening connection terminals, max. core cross-section 2 x 2.5 mm <sup>2</sup>
Mass		approx. 150 g
Dimensions		12.5 x 115 x 110 mm (0.5 x 4.5 x 4.3 in)
Construction type		modular terminal housing , see system description
Mounting		on 35 mm DIN mounting rail acc. to EN 60715:2001
Data for application in connection with Ex-areas		
EC-Type Examination Certificate		BAS 01 ATEX 7005 , for additional certificates see www.pepperl-fuchs.com
Group, category, type of protection		(a) II (1)GD, I (M1) [Ex ia Ga] IIC, [Ex ia Da] IIIC, [Ex ia Ma] I (-20 °C ≤ T <sub>amb</sub> ≤ 60 °C) [circuit(s) in zone 0/1/2]
Voltage	$U_o$	28 V
Current	I <sub>o</sub>	93 mA
Power	Po	650 mW
Supply		
Maximum safe voltage	$U_m$	250 V
Series resistance		min. 301 $\Omega$
Permissible connection values [EEx ia]		
Statement of conformity		TÜV 99 ATEX 1484 X , observe statement of conformity
Group, category, type of protection, temperature class		(x) II 3G Ex nA IIC T4 Gc [device in zone 2]
Directive conformity		
Directive 94/9/EC		EN 60079-0:2012, EN 60079-11:2012, EN 60079-15:2010
International approvals		
IECEx approval		IECEx BAS 09.0142
Approved for		[Ex ia Ga] IIC, [Ex ia Da] IIIC, [Ex ia Ma] I
General information		r
Supplementary information		EC-Type Examination Certificate, Statement of Conformity, Declaration of Conformity, Attestation of Conformity and instructions have to be observed where applicable. For information see www.pepperlfuchs.com.

