DATASHEET - DILM32-XP1



Paralleling link, for DILM17-32

DILM32-XP1 Part no. Catalog No. 281194 Alternate Catalog **XTCEXPLKC**

EL-Nummer 4110351

(Norway)



Delivery program

| Contact sequence | |
|---|--|
| Product range | Accessories |
| Accessories | Wiring accessories |
| For use with | DILM17 - DILM32 DILMF8 - DILMF32 |
| For use with | Paralleling links for DILM17 to DILM32 |
| Information about equipment supplied | consisting of 2 paralleling links |
| Instructions AC1 current carrying capacity of the open contactor increases by a fac Protected against accidental contact in accordance to VDE 0106 part 100 | tor of 2.5 |

Technical data

| Paral | _ | 10 | |
|-------|-----|-----|--|
| Parai | IPI | ппк | |

| Terminal capacities | | mm^2 | |
|--------------------------------|------------------|---------------|---------------|
| Solid | | mm^2 | 16 |
| Flexible with ferrule | | mm^2 | 1 x (16 - 35) |
| Stranded | | mm^2 | 1 x (16 - 50) |
| Tightening torque | | Nm | 4 |
| Tool | | | |
| Pozidriv screwdriver | | Size | 2 |
| Conventional thermal current | $I_{th} = I_{e}$ | Α | |
| 3 pole | I _{th} | Α | 100 |
| Rating data for approved types | | | |
| Short Circuit Current Rating | | SCCR | |
| Rasic Rating | | | |

| Short Circuit Current Rating | SCCR | |
|------------------------------|------|-----------------|
| Basic Rating | | |
| SCCR | kA | 5 |
| max. Fuse | Α | 125 |
| max. CB | Α | 125 |
| 480 V High Fault | | |
| SCCR (fuse) | kA | 10/100 |
| max. Fuse | Α | 125/70 Class J |
| SCCR (CB) | kA | 10/65 |
| max. CB | Α | 50/32 |
| 600 V High Fault | | |
| SCCR (fuse) | kA | 10/100 |
| max. Fuse | Α | 125/125 Class J |
| SCCR (CB) | kA | 10/22 |
| max. CB | Α | 50/32 |

Design verification as per IEC/EN 61439

| Technical data for design verification | | | |
|--|-------------------|----|--|
| Rated operational current for specified heat dissipation | In | Α | 115 |
| Heat dissipation per pole, current-dependent | P _{vid} | W | 0.1 |
| Equipment heat dissipation, current-dependent | P _{vid} | W | 0.3 |
| Static heat dissipation, non-current-dependent | P _{vs} | W | 0 |
| Heat dissipation capacity | P _{diss} | W | 0 |
| Operating ambient temperature min. | | °C | -25 |
| Operating ambient temperature max. | | °C | 60 |
| IEC/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | | Is the panel builder's responsibility. |
| 10.9 Insulation properties | | | |
| 10.9.2 Power-frequency electric strength | | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | | | Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:constraint}$ |
| 10.13 Mechanical function | | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. $\label{eq:continuous}$ |

Technical data ETIM 7.0

Low-voltage industrial components (EG000017) / Accessories for low-voltage switch technology (EC002498)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Component for low-voltage switching technology / Component for low-voltage switch technology (accessories) (ecl@ss10.0.1-27-37-13-92 [AKN570013])

Type of accessory Connecting bridge

Approvals

| Approvato | |
|--------------------------------------|---|
| Product Standards | IEC/EN 60947-4-1; UL 508; CSA-C22.2 No. 14-05; CE marking |
| UL File No. | E29096 |
| UL Category Control No. | NLDX |
| CSA File No. | 012528 |
| CSA Class No. | 3211-03 |
| North America Certification | UL listed, CSA certified |
| Specially designed for North America | No |