### **SPECIFICATIONS**

I <sup>2</sup> t for fusing 10ms	250 A <sup>2</sup> s	Min line voltage	5V ac
Max transient over volts	1200V ac	Max line voltage	440V ac
Max electrical isolation	3500V	Control signals	0-5V dc & 4-20mA
Power consumption	1 2 watts	Operating frequency	50 to 60 Hz +/- 5%
Max load current @ 65°C	25A	Supply voltage	10-18V ac
Min load current @ 65°C	0 05A	Peak one cycle surge	250A
Man. control potentiometer	5K	Max operating temp	0°C to 65°C
Power Terminals	M4 X 10mm	Max operating temp	-20°C to +85°C

### **FUSING**

It is recommended to use semiconductor fast acting type fuses or circuit breakers (Semiconductor-MCB) for unit/device protection. On initial 'switch on some loads may need an increased Factor of Safety (F of S) for unit and/or device protection.

(See the SRA Datasheet for further information).

COS

### CE MARKING

This product family carries a "CE marking". These phase angle controllers need a suitable remote filter. For information see recommendation section and contact our sales desk (See the Declaration of Conformity).

### RECOMMENDATION

1120 STRING TO THE STRING THE STRING TO THE				
Other documents available on request, which may be appropriate for your applications				
CODE	IDENTITY	DESCRIPTION		
X10229	RFI	Filtering recommendation - addressing EMC directive.		
X10213	ITA	Interaction uses for phase angle and for burst fire control		
X10255	SRA	Safety requirements - addressing the Low Voltage Directive		
		(LVD) including :-Thermal data/cooling ; "Live" parts warning		
		& Earth requirements: Fusing recommendations		

UAL Conditions of sale

NOTE It is recommended that installation and maintenance of this equipment should be done with reference to the current edition of the IE.E Wiring Regulations (BS7671) by suitably qualified/trained personnel. The regulations contain important requirements regarding safety of electrical equipment. (For International Standards refer to LE C Directive LE C 950).

### ORDER CODE:

AP02/4

State part number: Stom1

Optional extras include: Potentiometer Supply Transformer Heatsink compound Filter



### UNITED AUTOMATION LIMITED

1Southport Business Park Tel: 0044 (0) 1704 - 516500 Main Tel: 0044 (0) 1704 - 516516 Sales Southport, PR8 4HQ Fax: 0044 (0) 1704 - 516501 **ENGLAND** Enquiry@united-automation.com www.united-automation.com

Page No. 2 of 2 Issue 3







# MICROPROCESSOR BASED

# 25A AC POWER CONTROLLER

STOM1

X10223

The STOM1 is a microprocessor based power controller, with a built in power device that is capable of controlling up to 25A at voltages up to 440V ac. The STOM1 has two types of power control, Phase Angle and Burst Firing, either can be selected separately. The module can also be used for soft starting in Phase Angle mode and it will automatically switch to Burst Fire mode when the control signal has reached a preset level. The control will remain in the Burst Fire State even if the input signal drops below the preset level. The STOM1 also has a ramp up from cold, which can be set from 0 to 30 seconds. The controller will operate from a O to 5V dc or 4 to 20mA signal, these signal inputs are fully isolated and can be controlled from a Temperature Controller or PC etc. The STOM1 provides the equipment designer with flexibility in a wide range of applications

### **APPLICATIONS**

Suitable for most resistive loads including ovens, moulders, and dryers with current ratings up to 25A when fitted onto a suitable heatsink (1 3°C/W) Ideal for unusual heating loads which have very low resistance when cold

### **FEATURES**

Energy saving Simple wiring Isolated inputs

Soft start facility Standard 80mm fixing Rugged and compact

Phase angle or Burst firing Solid state reliability Integrated Power Device


### INSTALLATION

THE STOM1 AC POWER CONTROLLER SHOULD BE MOUNTED ON A CLEAN OR UNPAINTED METAL

THERMALLY CONDUCTIVE


SURFACE. USING HEAT SINK COMPOUND THINLY APPLIED BETWEEN THE CONTROLLER AND THE MOUNTING PLATE.

# DIMENSIONS



IN ORDER TO COMPLY WITH THE CURRENT EMC DIRECTIVE WHEN USING IN PHASE ANGLE MODE A LINE FILTER MUST BE USED.

WIRING AND CONNECTIONS



HIGH SPEED FUSE SHOULD BE USED TO PROTECT THE DEVICE UNIT SUPPLY MUST BE ISOLATED FROM MAINS & CONTROL SIGNAL

SWITCH OFF SUPPLY BEFORE COMMENCING ANY SERVICING WORK

CONTROL OFTIONS DC INPUT VOLTAGE CONTROL TERMINALS 3.4 AND 5 □ 3 = DV ☐ 4 = 0 TO 5V

☐ 5 = 5V OUTPUT ☐ 5K INPUT CURRENT CONTROL TERMINALS 3 AND 6 □ 3 = 0V

☐ 6 = 4-20mA ☐ 240R INPUT MODE A PHASE ANGLE TERMINAL A AND 5

17 A = 5V □ 5 = 5\/ MODE B BURST FIRE TERMINALS B AND S


□ B = 5V U 5 ≃ 5V NODE A AND B START IN PHASE ANGLE SWITCHING TO BURST FIRE TERMINAL A.B AND 5

□ A = 5V \_\_\_\_B = 5¥ **□** 5 = €V PHASE REFERENCE AND

SUPPLY TERMINALS 1 AND 2

10V TO 18V AC AT 75 mA

Real Sugarantal Line Directive 2002/93/56



### INSTALLATION

STOM1

## COOLING REQUIREMENTS

## HEATSINK CALCULATIONS

THIS APPLICATION NOTE PROVIDES ADDITIONAL INFORMATION AND SIMPLE CALCULATIONS TO ALLOW YOU TO DETERMINE A MAXIMUM PERMISSABLE HEATSINK THERMAL RESISTANCE FOR A GIVEN SET OF OPERATING CONDITIONS WHEN THE CONTROLLER IS ON THE TEMPERATURE, (T, MAX) AT THE SENICONDUCTOR JUNCTION WILL OBVIOUSLY BE HOTTER THAN THE ATTACHED HEATSINK. THIS IS DUE TO RESISTANCE TO HEAT TRANSFER WHICH IS CALLED THERMAL RESISTANCE AND IT IS MERSURED IN DEGREES CELCIUS PER MATT

PARAMETERS =

230V AC SUPPLY AT 25A AND A MAXIMUM AMBIENT AIR TEMPERATURE OF 50°C

- I FROM THE GRAPH BELOW FIND THE MAXIMUM POWER DISSIPATION FOR 258  $25R = 31~\mu ATTS$
- 2 CALCULATE THE TEMPERATURE DIFFERENCE BETWEEN T, AND THE HEATSINK 31 WATTS X 1.1°C/W = 34.1°C
- 3 T, MUST NOT RISE ABOUE 125°C
  - 125 34 1 = 90.9°C
- 4 THE MAXIMUM AMBIENT TEMPERATURE IS 50°C

90.9 - 50 = 40.9°C

5 DIVIDING THIS TEMPERATURE BY THE MATTAGE (1) GIVES  $40.9 \div 31 = 1.32^{\circ}\text{C/W}$ 

THEREFORE ANY HEATSINK OF 1 32°C/W OR LESS WILL BE SATISFACTORY

