


Certificate



Reference No. 817635

Miniature fuse-link

Type designation 179200

Certificate holder **SIBA GmbH & Co. KG**
Bereich ELU-Geraeteschutz
POSTFACH 1940
DE-44509 LÜNEN
GERMANY


The product complies with the standard(s) EN 60127-2:2003+A1

Date of expiry 27 January 2014

EU Directive information *The product satisfies the provisions for CE marking according to the Low Voltage Directive 2006/95/EC.*

Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed 
Anders Engberg Date 27 January 2009
Page 1 of 2

This certificate is issued in accordance with the terms and conditions set out in the Appendix.



Appendix

Reference No. 817635

Technical data


Type designation	179200
Rated voltage (V)	AC 250 V
Rated current (A)	1 A; 1.25 A; 1.6 A; 2 A; 2.5 A
Standard sheet	5
Brand name:	ELU
Product information	Time-lag, high-breaking capacity. Size 5 x 20 mm.

Manufacturing site(s)	SIBA GmbH & Co. KG Bereich ELU-Geräteschutz Borker Strasse 20-22 DE-44534 Lünen GERMANY
-----------------------	---

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 2006/95/EC.

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
--------------------	--	-------	-------------------

Signed



Anders Engberg

Date 27 January 2009

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.





Certificate

Product Safety

- with the right to S marking

Reference No / Referensnr. 204882

Miniature fuse-link

Type designation /
Typbeteckning

179200.3,15, 179200.4, 179200.5, 179200.6,3

Manufacturer /
Certifikatsinnehavare

SIBA SICHERUNGEN-BAU GMBH
Bereich ELU-Geraeteschutz
POSTFACH 1940
DE-44509 LÜNEN
GERMANY

The product complies with
the standard(s) /
Produkt uppfyller standard

EN 60127-2:1991 and A1

Date of expiry /
Giltigt längst t o m

31 December 2013

LVD Information

The product satisfies the provisions for CE marking according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.

Terms in SEMKO's Agreement on certification. Additional information in Appendix.

Certification Body /
Certifieringsorgan

SEMKO AB, Product Certification

Place / Kista - Stockholm
Ort

Signed /
Underskrift


Pär Zetterberg

Date / 3 February 2003
Datum



Intertek Testing Services
ETL SEMKO



Appendix

Reference No / Referensnr. 204882

Technical data / Tekniska data

Type designation / Typbeteckning 179200.3,15
Rated Voltage (V) / Märkspänning 250
Rated Current (A) / Märkström 3,15
Standard sheet / Normblad 5
Product information / Produktinformation Time-lag, high-breaking capacity. 5x20 mm

Type designation / Typbeteckning 179200.4
Rated Voltage (V) / Märkspänning 250
Rated Current (A) / Märkström 4
Standard sheet / Normblad 5
Product information / Produktinformation Time-lag, high-breaking capacity. 5x20 mm

Type designation / Typbeteckning 179200.5
Rated Voltage (V) / Märkspänning 250
Rated Current (A) / Märkström 5
Standard sheet / Normblad 5
Product information / Produktinformation Time-lag, high-breaking capacity. 5x20 mm

Type designation / Typbeteckning 179200.6,3
Rated Voltage (V) / Märkspänning 250
Rated Current (A) / Märkström 6,3
Standard sheet / Normblad 5
Product information / Produktinformation Time-lag, high-breaking capacity. 5x20 mm

Manufacturing site(s) /
Tillverkningsställe(n) SIBA SICHERUNGEN-BAU GMBH
Borker Strasse 20-22
DE-44534 LÜNEN
GERMANY

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the products according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.

Kista/Stockholm
3 February 2003


Pär Zetterberg

Page / Sid 1 (1)