

27 July 2023

Product Change Notification

PCN ID: 3A01

Description/ Purpose of change	HI-POT test screw indicator on enclosure			
Article category	DIN-Rail DRB3 series			
Change category	Form	Fit	X	Function



Detailed description

Dear customer / valued partner


As a technology driven company we are continuously striving for improvements on our products and to follow the latest technical standards.

Please find here the detailed change information and the affected part numbers.

Series	DRB3
Part numbers	DRB120-12-3-A0, DRB120-12-3-A1, DRB120-24-3-A0, DRB120-24-3-A1, DRB240-24-3-A0, DRB240-24-3-A1, DRB240-48-3-A0, DRB240-48-3-A1
Change	Additional engraving on the enclosure to indicate the ground connection screw of the GDT (gas discharge tube). In case of a field HI-POT test the screw must be disconnected. The detailed instruction can be found on the technical product specifications under chapter 13.3.

	Previous state	New state
Description		
Revision	D06	D07

CN00003A01_DRB3-series_HI-POT test screw_TDK-Lambda.docx

Series	DRB3	
Part numbers	DRB480-24-3-A0, DRB480-24-3-A1, DRB480-48-3-A0, DRB480-48-3-A1	
Change	Additional engraving on the enclosure to indicate the ground connection screw of the GDT (gas discharge tube). In case of a field HI-POT test the screw must be disconnected. The detailed instruction can be found on the technical product specifications under chapter 13.3.	
	Previous state	New state
Description		
Revision	D01	D02



Implementation information

Effective Date	October 2023
-----------------------	--------------

Contact information

If you require any assistance or further information relating to this notice, please contact your local sales representative.

Name	Email	Phone
Thorsten Osteroth	thorsten.osteroth@tdk.com	+49 170 6352582

The overall product documentation can be found on our website [TDK-Lambda Product Center](#).

We are looking forward to offering you new products and services in the future.

Kind regards,

TDK-Lambda
Global DIN-Rail Division

CN00003A01_DRB3-series_HI-POT test screw_TDK-Lambda.docx