SIEMENS

Data sheet

3RH2911-4HA31



AUX.SWITCH BLOCK,FRONT,3NO+1NC, CURR.PATH: 1NC, 1NO, 1NO, 1NO, F. CONT. RELAYS A. MOTOR CONT., 3RT2 RING CABLE LUG CONNECTION .1 / .2,3 / .4,3 / .4,3 / .4

General technical data:				
product brand name		SIRIUS		
Suitability for use		Contactor relay and power contactor		
Protection class IP on the front		IP20		
Ambient temperature				
during storage	°C	-55 +80		
 during operation 	°C	-25 +60		
Mechanical service life (switching cycles) typical		10 000 000		
Electrical endurance (switching cycles) at AC-15 at 230 V typical		200 000		
Contact reliability		one incorrect switching operation of 100 million switching operations (17 V, 1 mA)		
Contact reliability of the auxiliary contacts		1 faulty switching per 100 million (17 V, 1 mA)		
Insulation voltage with degree of pollution 3 Rated value	V	690		
Surge voltage resistance Rated value	kV	6		
Auxiliary circuit:				
Number of NC contacts for auxiliary contacts				
 instantaneous contact 		1		
 lagging switching 		0		
Number of NO contacts for auxiliary contacts				
 instantaneous contact 		3		
 leading contact 		0		
Operating current of the auxiliary contacts at AC-12				
• at 24 V	А	10		

• maximum A 0 Operating current • 10 • of the auxiliary contacts - - - at AC-14 - - - at 250 V A 6 - at 250 V A 6 - at 220 V A 6 - at 230 V A 6 - at 24 V A 6 - at 400 V A 3 • at AC-15 at 690 V Rated value A 1 - at 400 V A 6 - at 400 V A 6 - at 400 V Rated value A 10 - at 40 V Rated value A 10 - at 20 V Rated value A 0.65 - at 400 V Rated value A 0.65 - at 400 V Rated value A 10 - at 20 V Rated value A 1.8	a = t 000) /	٨	10
Operating currentImage: contracts $- at AC-14$ A $- at 25 V$ A $- at 24 V$ A $- at 230 V$ A $- at 400 V$ Rated valueA $- at 24 V Rated valueA- at 20 V Rated valueA- at 400 V Rated valueA- at 400 V Rated valueA- at 20 V Rated valueA- at 400 V Rated valueA- at 20 V Rated valueA- at 60 V Rated valueA- at 60 V Rated valueA- at 20 V Rated valueA- at 24 V Rated valueA- at 24 V Rated valueA- at 20 V Rated valueA- at 24 V Rated valueA$	• at 230 V	A	
• of the auxiliary contacts		A	10
-at AC-14 A 6 $-at 250 V$ A 6 $-at 250 V$ A 6 $-at 250 V$ A 6 $-at 24 V$ A 6 $-at 230 V$ A 6 $-at 230 V$ A 6 $-at 230 V$ A 6 $-at 400 V$ A 3 $-at 400 V$ Rated value A 1 Operating current A 10 $-at 24 V$ Rated value A 10 $-at 20 V$ Rated value A 10 $-at 20 V$ Rated value A 10 $-at 20 V$ Rated value A 1.3 $-at 400 V$ Rated value A 0.655 $-at 400 V$ Rated value A 10 $-at 60 V$ Rated value A 10 $-at 21 V$ Rated value A 10 $-at 410 V$ Rated value A 10 $-at 410 V$ Rated value A 1.3 $-at 60 V$ Rated value A 1.4 $-at 60 V$ Rated value A 1.4 <td< td=""><td></td><td></td><td></td></td<>			
- at 250 V A 6 - at 24 V A 6 - at 23 V A 6 - at 230 V A 6 - at 240 V A 3 - at 400 V A 3 • at A00 V A 10 - at 400 V A 10 - at 24 V Rated value A 10 - at 20 V Rated value A 10 - at 20 V Rated value A 10 - at 20 V Rated value A 10 - at 60 V Rated value A 10 - at 210 V Rated value A 10 - at 400 V Rated value A 0.55 • with 3 current paths in series at DC-12 - - - at 40 V Rated value A 10 - - at 40 V Rated value A 10 - - at 40 V Rated value A 10 - - at 40 V Rated value A 10 - - at 40 V Rated value A 2.5 - - at 400 V Rated value A 2.5 -			
$- \operatorname{at} \operatorname{AC-15}$ $- \operatorname{at} 24 \operatorname{V}$ A 6 $- \operatorname{at} 230 \operatorname{V}$ $- \operatorname{at} 400 \operatorname{V}$ A 3 $- \operatorname{at} 400 \operatorname{V}$ A 3 $- \operatorname{at} 400 \operatorname{V}$ A 4 1 $- \operatorname{at} 20 \operatorname{V} \operatorname{Rated value}$ A 1 $- \operatorname{at} 20 \operatorname{V} \operatorname{Rated value}$ A 10 $- \operatorname{at} 60 \operatorname{V} \operatorname{Rated value}$ A 10 $- \operatorname{at} 20 \operatorname{V} \operatorname{Rated value}$ A 10 $- \operatorname{at} 20 \operatorname{V} \operatorname{Rated value}$ A 10 $- \operatorname{at} 20 \operatorname{V} \operatorname{Rated value}$ A 13 $- \operatorname{at} 600 \operatorname{V} \operatorname{Rated value}$ A 10 $- \operatorname{at} 20 \operatorname{V} \operatorname{Rated value}$ A 13 $- \operatorname{at} 600 \operatorname{V} \operatorname{Rated value}$ A 10 $- \operatorname{at} 20 \operatorname{V} \operatorname{Rated value}$ A 10 $- \operatorname{at} 60 \operatorname{V} \operatorname{Rated value}$ A 10 $- \operatorname{at} 20 \operatorname{V} \operatorname{Rated value}$ A 25 $- \operatorname{at} 600 \operatorname{V} \operatorname{Rated value}$ A 1.8 $Coerating current$ $- \operatorname{at} 20 \operatorname{V} \operatorname{V} \operatorname{Rated value}$ A 1.8 $Coerating current$ $- \operatorname{at} 20 \operatorname{V}$ $A = 0$ 3.6 $- \operatorname{at} 40 \operatorname{V} \operatorname{Rated value}$ A 1.8 $Coerating current$ $- \operatorname{at} 20 \operatorname{V}$ $A = 0$ 3.6 $- \operatorname{at} 40 \operatorname{V} \operatorname{Rated value}$ A 1.8 $Coerating current$ $- \operatorname{at} 20 \operatorname{V}$ $A = 0$ 3.6 $- \operatorname{at} 40 \operatorname{V} \operatorname{Rated value}$ A 1.8 $Coerating current paths in series at DC-13$ $- \operatorname{at} 220 \operatorname{V}$ $A = 0$ 3.5 $- \operatorname{at} 24 \operatorname{V}$ $A = 0$ 3.5 $- \operatorname{at} 24 \operatorname{V} \operatorname{Rated value}$ A 3.5 $- \operatorname{at} 22 \operatorname{V} \operatorname{Rated value}$ A 3.5 $- \operatorname{at} 410 \operatorname{V} \operatorname{Rated value}$ A 3.5 $- \operatorname{at} 410$			
$-at 24 V$ A 6 $-at 230 V$ A 6 $-at 400 V$ A 3 \bullet at AC:15 at 690 V Rated value A 1 Operating current \bullet with 2 current paths in series at DC-12 - $-at 24 V Rated value A 10 -at 24 V Rated value A 4 -at 220 V Rated value A 4 -at 220 V Rated value A 2 -at 440 V Rated value A 0.655 \bullet with 3 current paths in series at DC-12 - -at 60 V Rated value A 10 -at 220 V Rated value A 10 -at 440 V Rated value A 10 -at 60 V Rated value A 10 -at 410 V Rated value A 10 -at 42 V V Rated value A 18 Operating current - - -at 60 V V Rated value A 1 -at 22 V V A 6 -at 110 V V Rated value A 1 -at 60 V V Rated value A 1<$		A	6
- at 230 V A 6 - at 400 V A 3 • at AC-15 at 690 V Rated value A 1 Operating current • with 2 current paths in series at DC-12 A 10 - at 24 V Rated value A 10 - at 60 V Rated value A 4 - at 220 V Rated value A 4 - at 220 V Rated value A 2 - at 400 V Rated value A 0.655 • with 3 current paths in series at DC-12 A 10 - at 600 V Rated value A 10 - at 600 V Rated value A 10 - at 10 V Rated value A 10 - at 220 V Rated value A 10 - at 600 V Rated value A 18 Operating current A 6 • of the auxiliary contacts at DC-13 - - - at 600 V Rated value A 6 - at 60 V A 2 - at 60 V A 1 -			
		A	6
• at AC-15 at 690 V Rated valueA1Operating current• with 2 current paths in series at DC-12 at 24 V Rated valueA10- at 60 V Rated valueA10- at 110 V Rated valueA2- at 440 V Rated valueA1.3- at 440 V Rated valueA0.65• with 3 current paths in series at DC-12 at 24 V Rated valueA10- at 400 V Rated valueA10- at 400 V Rated valueA25- at 600 V Rated valueA1.8Operating current• of the auxiliary contacts at DC-13 at 220 VA6- at 220 VA0.3- at 220 VA1- at 220 V Rated valueA1- at 220 V Rated valueA1- at 220 V Rated valueA10- at 110 V Rated valueA1.3- at 220 V Rated valueA<	— at 230 V	A	6
Operating currentA• with 2 current paths in series at DC-12A- at 24 V Rated valueA- at 60 V Rated valueA- at 60 V Rated valueA- at 110 V Rated valueA- at 220 V Rated valueA- at 220 V Rated valueA- at 440 V Rated valueA- at 600 V Rated valueA- at 24 V Rated valueA- at 600 V Rated valueA- at 110 V Rated valueA- at 220 V Rated valueA- at 600 V Rated valueA- at 220 V Rated valueA- at 24 V Rated valueA- at 24 VA- at 600 V Rated valueA- at 220 VA- at 600 V Rated valueA- at 220 V Rated value <td< td=""><td>— at 400 V</td><td>A</td><td>3</td></td<>	— at 400 V	A	3
• with 2 current paths in series at DC-12I $-$ at 24 V Rated valueA10 $-$ at 60 V Rated valueA4 $-$ at 220 V Rated valueA2 $-$ at 440 V Rated valueA1.3 $-$ at 600 V Rated valueA0.65 $-$ at 440 V Rated valueA10 $-$ at 440 V Rated valueA10 $-$ at 440 V Rated valueA10 $-$ at 600 V Rated valueA10 $-$ at 440 V Rated valueA10 $-$ at 24 V Rated valueA10 $-$ at 24 V Rated valueA10 $-$ at 24 V Rated valueA10 $-$ at 600 V Rated valueA10 $-$ at 600 V Rated valueA2.5 $-$ at 600 V Rated valueA1.8Operating current $-$ at 24 VA6 $-$ at 60 VA2 $-$ at 60 V NA2 $-$ at 60 VA1 $-$ at 220 VA1 $-$ at 24 VA6 $-$ at 24 VA6 $-$ at 24 VA6 $-$ at 60 VA2 $-$ at 24 VA1 $-$ at 24 VA1 $-$ at 24 VA6 $-$ at 24 VA1 $-$ at 24 VA1 $-$ at 24 VA1 $-$ at 24 VA1 $-$ at 60 V Rated valueA15 $-$ at 60 V Rated valueA13 <trr< td=""><td>• at AC-15 at 690 V Rated value</td><td>A</td><td>1</td></trr<>	• at AC-15 at 690 V Rated value	A	1
- at 24 V Rated valueA10 $-$ at 60 V Rated valueA4 $-$ at 110 V Rated valueA4 $-$ at 220 V Rated valueA2 $-$ at 440 V Rated valueA1.3 $-$ at 600 V Rated valueA0.65• with 3 current paths in series at DC-12- $-$ at 60 V Rated valueA10 $-$ at 60 V Rated valueA10 $-$ at 60 V Rated valueA10 $-$ at 60 V Rated valueA3.6 $-$ at 440 V Rated valueA3.6 $-$ at 440 V Rated valueA2.5 $-$ at 600 V Rated valueA6 $-$ at 24 VA6 $-$ at 24 VA6 $-$ at 24 VA1 $-$ at 24 VA1 $-$ at 24 VA1 $-$ at 24 VA6 $-$ at 24 VA6 $-$ at 24 VA1 $-$ at 20 VA0.3 $-$ at 21 V VA1 $-$ at 22 V V Rated valueA1.3 $-$ at 24 V Rated valueA0.9 $-$ at 40 V Rated value <td></td> <td></td> <td></td>			
	 with 2 current paths in series at DC-12 		
In the formation of the	— at 24 V Rated value	A	10
$-at 220 \vee Rated valueA2-at 440 \vee Rated valueA1.3-at 600 \vee Rated valueA0.65• with 3 current paths in series at DC-12--at 24 \vee Rated valueA10-at 60 \vee Rated valueA10-at 10 \vee Rated valueA10-at 220 \vee Rated valueA3.6-at 440 \vee Rated valueA2.5-at 600 \vee Rated valueA1.8Operating current-at 24 \veeA6-at 24 \veeA6-at 60 \veeA2-at 60 \veeA2-at 110 \veeA1-at 220 \veeA0.3\bullet with 2 current paths in series at DC-13--at 24 \veeA6-at 220 \veeA0.3\bullet with 2 current paths in series at DC-13--at 21 \vee Rated valueA10-at 220 \veeA0.3\bullet with 2 current paths in series at DC-13--at 21 \vee Rated valueA10-at 220 \veeA0.3\bullet with 2 current paths in series at DC-13--at 40 \vee Rated valueA1.3-at 20 \vee Rated valueA1.3-at 40 \vee Rated valueA0.9-at 4110 \vee Rated valueA0.9-at 440 \vee Rated valueA0.2-at 440 \vee Rated valueA0.2-at 440 \vee Rated valueA0.1$	— at 60 V Rated value	A	10
$-at 440 \vee Rated value$ A1.3 $-at 600 \vee Rated value$ A0.65• with 3 current paths in series at DC-12- $-at 24 \vee Rated value$ A10 $-at 60 \vee Rated value$ A10 $-at 10 \vee Rated value$ A3.6 $-at 220 \vee Rated value$ A2.5 $-at 60 \vee Rated value$ A1.8Operating current $-at 24 \vee$ A6 $-at 60 \vee Rated value$ A2.5 $-at 60 \vee Rated value$ A1.8Operating current $-at 24 \vee$ A6 $-at 60 \vee$ A2 $-at 110 \vee$ A1 $-at 20 \vee$ A0.3 $-at 20 \vee$ A0.3 $-at 20 \vee$ A10 $-at 20 \vee$ A10 $-at 20 \vee$ A10 $-at 20 \vee$ A10 $-at 20 \vee$ A0.3 $-at 20 \vee$ A10 $-at 20 \vee$ A10 $-at 20 \vee$ A10 $-at 20 \vee$ A3.5 $-at 110 \vee$ A1.3 $-at 20 \vee$ A3.5 $-at 110 \vee$ A1.3 $-at 20 \vee$ A0.9 $-at 440 \vee$ A0.9 $-at 440 \vee$ A0.2 $-at 460 \vee$ A0.2 <tr< td=""><td>— at 110 V Rated value</td><td>A</td><td>4</td></tr<>	— at 110 V Rated value	A	4
- at 600 V Rated valueA0.65• with 3 current paths in series at DC-12- $-$ at 24 V Rated valueA10 $-$ at 60 V Rated valueA10 $-$ at 60 V Rated valueA10 $-$ at 110 V Rated valueA3.6 $-$ at 220 V Rated valueA2.5 $-$ at 600 V Rated valueA1.8Operating current $-$ at 24 VA6 $-$ at 60 VA2 $-$ at 60 VA2 $-$ at 60 VA2 $-$ at 60 VA1 $-$ at 24 VA6 $-$ at 60 VA2 $-$ at 24 VA6 $-$ at 24 VA1 $-$ at 60 VA3.6 $-$ at 24 VA6 $-$ at 24 VA6 $-$ at 24 VA6 $-$ at 24 VA1 $-$ at 60 VA2 $-$ at 60 VA3.6 $-$ at 220 VA0.3 $-$ at 220 VA3.5 $-$ at 110 V Rated valueA3.5 $-$ at 110 V Rated valueA1.3 $-$ at 220 V Rated valueA0.9 $-$ at 440 V Rated valueA0.2 $-$ at 440 V Rated valueA0.2 $-$ at 600 V Rated valueA0.2 $-$ at 600 V Rated valueA0.1	— at 220 V Rated value	A	2
 with 3 current paths in series at DC-12 at 24 V Rated value at 60 V Rated value at 10 V Rated value at 10 V Rated value at 220 V Rated value A at 220 V Rated value A 3.6 at 440 V Rated value A 2.5 at 600 V Rated value A 1.8 Operating current of the auxiliary contacts at DC-13 at 220 V A Current paths in series at DC-13 at 220 V A Current paths in series at DC-13 at 220 V A Current paths in series at DC-13 at 220 V A Current paths in series at DC-13 at 24 V Rated value A Current paths in series at DC-13 at 220 V A Current paths in series at DC-13 at 220 V A Current paths in series at DC-13 at 220 V A Current paths in series at DC-13 at 220 V A Current paths in series at DC-13 at 220 V A Current paths in series at DC-13 at 220 V A Current paths in series at DC-13 at 220 V A Current paths in series at DC-13 at 424 V Rated value A Current paths in series at DC-13 A Current paths in series at DC-13 A A Current paths in series at DC-13 Current paths in series at DC-13 Current	— at 440 V Rated value	А	1.3
- at 24 V Rated valueA10- at 60 V Rated valueA10- at 110 V Rated valueA3.6- at 220 V Rated valueA2.5- at 440 V Rated valueA1.8Operating current at 24 VA6- at 60 VA2- at 60 VA2- at 60 VA1- at 220 VA0.3- at 220 VA1- at 220 VA0.3- at 220 VA3.5- at 60 V Rated valueA1.3- at 20 V Rated valueA1.3- at 20 V Rated valueA0.9- at 110 V Rated valueA0.9- at 20 V Rated valueA0.9- at 40 V Rated valueA0.9- at 110 V Rated valueA0.2- at 200 V Rated valueA0.2- at 400 V Rated valueA0.2- at 400 V Rated valueA0.1	— at 600 V Rated value	А	0.65
at 60 V Rated valueA10 at 110 V Rated valueA10 at 220 V Rated valueA3.6 at 440 V Rated valueA2.5 at 600 V Rated valueA1.8Operating current at 24 VA6 at 60 VA2 at 60 VA2 at 60 VA1 at 110 VA1 at 220 VA0.3 at 24 V Rated valueA10 at 24 V Rated valueA3.5 at 24 V Rated valueA1.3 at 24 V Rated valueA0.9 at 24 V Rated valueA0.9 at 24 V Rated valueA0.2 at 24 V Rated valueA0.2 at 24 V Rated valueA0.2 at 240 V Rated valueA0.1	 with 3 current paths in series at DC-12 		
 at 110 V Rated value at 110 V Rated value at 220 V Rated value A 3.6 at 440 V Rated value A 2.5 at 600 V Rated value A 1.8 Operating current of the auxiliary contacts at DC-13 - at 24 V A 6 - at 60 V A 2 - at 110 V A 1 - at 220 V A 0.3 with 2 current paths in series at DC-13 - at 24 V Rated value A 10 - at 24 V Rated value A 10 - at 24 V Rated value A 0.3 - at 110 V Rated value A 0.3 - at 24 V Rated value A 0.3 - at 24 V Rated value A 0.3 - at 24 V Rated value A 0.3 - at 220 V Rated value A 0.1 	— at 24 V Rated value	А	10
- at 220 V Rated valueA3.6- at 440 V Rated valueA2.5- at 600 V Rated valueA1.8Operating current-• of the auxiliary contacts at DC-13 at 24 VA6- at 60 VA2- at 110 VA1- at 220 VA0.3• with 2 current paths in series at DC-13 at 24 V Rated valueA10- at 24 V Rated valueA3.5- at 24 V Rated valueA3.5- at 24 V Rated valueA3.5- at 24 V Rated valueA0.9- at 440 V Rated valueA0.2- at 440 V Rated valueA0.2- at 600 V Rated valueA0.1	— at 60 V Rated value	А	10
- at 440 V Rated valueA2.5- at 600 V Rated valueA1.8Operating current-• of the auxiliary contacts at DC-13 at 24 VA6- at 60 VA2- at 110 VA1- at 220 VA0.3• with 2 current paths in series at DC-13 at 24 V Rated valueA3.5- at 20 VA3.5- at 20 V Rated valueA1.3- at 20 V Rated valueA0.9- at 440 V Rated valueA0.2- at 440 V Rated valueA0.2- at 600 V Rated valueA0.1	— at 110 V Rated value	А	10
- at 600 V Rated valueA1.8Operating current• of the auxiliary contacts at DC-13 at 24 VA6- at 60 VA2- at 110 VA1- at 220 VA0.3• with 2 current paths in series at DC-13 at 24 V Rated valueA10- at 20 V Rated valueA3.5- at 20 V Rated valueA1.3- at 20 V Rated valueA0.9- at 4110 V Rated valueA0.2- at 440 V Rated valueA0.2- at 600 V Rated valueA0.1	— at 220 V Rated value	А	3.6
Operating currentImage: Constraint of the auxiliary contacts at DC-13Image: Constraint of the auxiliary contacts at DC-13- at 24 VA6- at 60 VA2- at 10 VA1- at 220 VA0.3• with 2 current paths in series at DC-13	— at 440 V Rated value	А	2.5
 of the auxiliary contacts at DC-13 - at 24 V - at 60 V - at 110 V - at 110 V - at 220 V A 0.3 • with 2 current paths in series at DC-13 - at 24 V Rated value A 10 - at 60 V Rated value A 3.5 - at 110 V Rated value A 1.3 - at 220 V Rated value A 0.9 - at 440 V Rated value A 0.2 - at 600 V Rated value A 0.1 	— at 600 V Rated value	А	1.8
- at 24 V A 6 - at 60 V A 2 - at 110 V A 1 - at 220 V A 0.3 • with 2 current paths in series at DC-13 - - - at 24 V Rated value A 10 - at 24 V Rated value A 3.5 - at 60 V Rated value A 1.3 - at 220 V Rated value A 0.9 - at 440 V Rated value A 0.2 - at 600 V Rated value A 0.1	Operating current		
at 60 V A 2 at 110 V A 1 at 220 V A 0.3 • with 2 current paths in series at DC-13 - at 24 V Rated value A 10 at 60 V Rated value A 3.5 at 110 V Rated value A 1.3 at 220 V Rated value A 0.9 at 440 V Rated value A 0.2 at 600 V Rated value A 0.1	 of the auxiliary contacts at DC-13 		
at 110 VA1 at 220 VA0.3• with 2 current paths in series at DC-13 at 24 V Rated valueA10 at 60 V Rated valueA3.5 at 110 V Rated valueA1.3 at 220 V Rated valueA0.9 at 440 V Rated valueA0.2 at 600 V Rated valueA0.1	— at 24 V	А	6
at 220 VA0.3• with 2 current paths in series at DC-13A10 at 24 V Rated valueA10 at 60 V Rated valueA3.5 at 110 V Rated valueA1.3 at 220 V Rated valueA0.9 at 440 V Rated valueA0.2 at 600 V Rated valueA0.1	— at 60 V	А	2
 with 2 current paths in series at DC-13 at 24 V Rated value at 60 V Rated value at 10 at 110 V Rated value A 3.5 at 220 V Rated value A 0.9 at 440 V Rated value A 0.2 at 600 V Rated value A 0.1 	— at 110 V	А	1
at 24 V Rated valueA10 at 60 V Rated valueA3.5 at 110 V Rated valueA1.3 at 220 V Rated valueA0.9 at 440 V Rated valueA0.2 at 600 V Rated valueA0.1	— at 220 V	А	0.3
at 60 V Rated valueA3.5 at 110 V Rated valueA1.3 at 220 V Rated valueA0.9 at 440 V Rated valueA0.2 at 600 V Rated valueA0.1	• with 2 current paths in series at DC-13		
at 110 V Rated valueA1.3 at 220 V Rated valueA0.9 at 440 V Rated valueA0.2 at 600 V Rated valueA0.1	— at 24 V Rated value	А	10
at 220 V Rated valueA0.9 at 440 V Rated valueA0.2 at 600 V Rated valueA0.1	— at 60 V Rated value	А	3.5
at 440 V Rated valueA0.2 at 600 V Rated valueA0.1	— at 110 V Rated value	А	1.3
— at 600 V Rated value A 0.1	— at 220 V Rated value	А	0.9
	— at 440 V Rated value	А	0.2
• with 3 current paths in series at DC-13	— at 600 V Rated value	А	0.1
	 with 3 current paths in series at DC-13 		

— at 24 V Rated value	А	10
— at 60 V Rated value	А	4.7
— at 110 V Rated value	А	3
— at 220 V Rated value	А	1.2
— at 440 V Rated value	А	0.5
— at 600 V Rated value	А	0.26

Installation/ mounting/ dimensions:			
Mounting type	snap-on mounting		
Width	mm	36	
Height	mm	37.5	
Depth	mm	43.7	

Connections/ Terminals:	
Type of electrical connection for auxiliary and control	ring cable connection
current circuit	
Safety related data:	
Product function Mirror contact acc. to IEC 60947-4-1	Yes

• Note	with 3RT2
Product function positively driven operation acc. to IEC 60947-5-1	Yes
• Note	with 3RH2

Certificates/ approvals:General Product ApprovalDeclaration of
ConformityTest
Certificates $\overbrace{\mathsf{Ccc}}_{\mathsf{Ccc}}$ $\overbrace{\mathsf{CsA}}^{\mathsf{Special Test}}$ $\overbrace{\mathsf{UL}}^{\mathsf{UL}}$ $\overbrace{\mathsf{Eff}}_{\mathsf{Eff}}$ $\overbrace{\mathsf{Eg-Konf.}}^{\mathsf{Special Test}}$

Test Certificates	Shipping App	proval			
Type Test Certificates/Test Report	ABS	BUREAU VERITAS	Ĵ Å DNV DNV	GL GL	Llovd's Register LRS
Shipping Approv	val		other		
PRS	RINA	RMRS	Environmental Confirmations		

⁻urther information

Information- and Downloadcenter (Catalogs, Brochures,...) http://www.siemens.com/industrial-controls/catalogs

Industry Mall (Online ordering system)

http://www.siemens.com/industrymall

Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3RH29114HA31

Service&Support (Manuals, Certificates, Characteristics, FAQs,...) http://support.automation.siemens.com/WW/view/en/3RH29114HA31/all

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...) http://www.automation.siemens.com/bilddb/index.aspx?attID9=3RH29114HA31&lang=en









