



Arc Fault Circuit Interrupter, 2 poles, C16A, 30mA, type A

Part no. AFDD-16/2/C/003-A
Article no. 187210

Similar to illustration

Delivery programme

| | | | |
|--|----------------|----|--|
| Basic function | | | Arc fault circuit interrupter |
| Number of poles | | | 2 pole |
| Tripping characteristic | | | C |
| Application | | | Switchgear for residential and commercial applications |
| Rated current | I_n | A | 16 |
| Rated switching capacity according to IEC/EN 60898-1 | | kA | 10 |
| Rated switching capacity according to IEC/EN 61009 | | kA | 10 |
| Rated short-circuit strength | I_{cn} | kA | 10 |
| Rated fault current | $I_{\Delta N}$ | A | 0.03 |
| Type | | | Type A |
| Tripping | | A | non-delayed |
| Type | | | ZV-SS |
| Product range | | | AFDD |
| Sensitivity | | | AC current sensitive |
| Impulse withstand current | | | Partly surge-proof 250 A |

Technical data

Electrical

| | | | |
|---------------------------------------|----------|------------|------------------------------|
| Types conform to | | | IEC/EN 62606 IEC/EN 61009 |
| Current test marks | | | As per inscription |
| Limit values of the operating voltage | | | |
| Test circuit | | V AC | 170 - 264 |
| Sensitivity | | | AC current sensitive |
| Rated short-circuit strength | I_{cn} | kA | 10 |
| lifespan | | | |
| Electrical | | Operations | 4000 |
| Mechanical | | Operations | 20000 |

Mechanical

| | | | |
|--|--|----|--|
| Standard front dimension | | mm | 45 |
| Device height | | mm | 80 |
| Built-in width | | mm | 54 (3TE) |
| Mounting | | | Tristable slide catch enables removal from existing combination. |
| Degree of Protection | | | IP20 switches IP 40 enclosed |
| Terminals top and bottom | | | Maul/Liftklemmen |
| Terminal protection | | | Berührungsschutz nach VBG4, ÖVE-EN 6 |
| Thickness of busbar material | | mm | 0.8 - 2 |
| Admissible ambient temperature range | | °C | -25 - +40 |
| Permissible storage and transport temperatures | | °C | -35 - +60 |
| Climatic proofing | | | gemäß IEC/EN 61009 |
| Contact position indicator | | | red / green |

Design verification as per IEC/EN 61439

| | | | |
|--|-------|---|----|
| Technical data for design verification | | | |
| Rated operational current for specified heat dissipation | I_n | A | 16 |

| | | | |
|--|------------------|---|--|
| Equipment heat dissipation, current-dependent | P _{vid} | W | 5 |
| IEC/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | | Is the panel builder's responsibility. |
| 10.9 Insulation properties | | | |
| 10.9.2 Power-frequency electric strength | | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 6.0

| | | | |
|--|--|----|------------------------|
| Circuit breakers and fuses (EG000020) / Earth leakage circuit breaker with auxiliary device (EC002695) | | | |
| Electric engineering, automation, process control engineering / Electrical installation, device / Residual current protection system / Earth leakage circuit breaker with auxiliary device (ecI@ss8.1-27-14-22-13 [ADI479004]) | | | |
| Number of poles | | | 2 |
| Nominal rated voltage | | V | 230 |
| Nominal rated current | | A | 16 |
| Rated fault current | | A | 0.03 |
| Leakage current type | | | A |
| Current limiting class | | | 3 |
| Rated short-circuit breaking capacity EN 60898 | | kA | 10 |
| Rated short-circuit breaking capacity IEC 60947-2 | | kA | 0 |
| Frequency | | Hz | 50 |
| Release characteristic | | | C |
| Concurrently switching N-neutral | | | No |
| Over voltage category | | | 3 |
| Pollution degree | | | 2 |
| Width in number of modular spacings | | | 3 |
| Built-in depth | | mm | 67 |
| Additional equipment attached at delivery | | | Fire protection switch |
| Rated switch current auxiliary device | | A | 0 |
| Rated voltage auxiliary device | | V | 230 |
| Control voltage type auxiliary equipment | | | AC |
| Degree of protection (IP) | | | IP20 |