SIEMENS

Data sheet 3RT1466-6AF36



CONTACTOR, 400A/AC-1 AC(40...60HZ)/DC
OPERATION UC 110-127V AUXILIARY CONTACTS
2NO+2NC 3-POLE, SIZE S10 BAR CONNECTIONS
CONVENT. OPERATING MECHANISM

Figure similar

product brand name

SIRIUS

Product designation

power contactor

		Pro Control Control
General technical data:		
Insulation voltage		
Rated value	V	1 000
Degree of pollution		3
Surge voltage resistance Rated value	kV	8
Mechanical service life (switching cycles)		
• of the contactor typical		10 000 000
of the contactor with added electronics-		5 000 000
compatible auxiliary switch block typical		40.000.000
 of the contactor with added auxiliary switch block typical 		10 000 000
Thermal short-time current restricted to 10 s	Α	2 400
Protection class IP		
• on the front		IP00
• of the terminal		IP00
Equipment marking		
• acc. to DIN EN 61346-2		Q
• acc. to DIN EN 81346-2		Q
Aain circuit:		
Number of poles for main current circuit		3
Number of NC contacts for main contacts		0
Number of NO contacts for main contacts		3

Operating current

• ot AC 1		
• at AC-1	Α	400
 — at 400 V at ambient temperature 40 °C Rated value 	^	400
— up to 690 V at ambient temperature 40 °C	Α	400
Rated value		
— up to 690 V at ambient temperature 60 °C	Α	380
Rated value		
• at AC-3		
— at 400 V Rated value	Α	138
— at 690 V Rated value	Α	138
Operating current with 1 current path		
• at DC-1		
— at 24 V Rated value	Α	380
— at 110 V Rated value	Α	33
• at DC-3 at DC-5		
— at 24 V Rated value	Α	380
— at 110 V Rated value	Α	3
Operating current with 2 current paths in series	_	
• at DC-1		
— at 24 V Rated value	Α	380
— at 110 V Rated value	Α	380
• at DC-3 at DC-5		
— at 110 V Rated value	Α	380
— at 24 V Rated value	Α	380
Operating current with 3 current paths in series		
• at DC-1		
— at 24 V Rated value	Α	380
— at 110 V Rated value	Α	380
• at DC-3 at DC-5		
— at 110 V Rated value	Α	380
— at 24 V Rated value	Α	380
Operating power		
• at AC-1 at 400 V Rated value	kW	250
• at AC-2 at 400 V Rated value	kW	75
Operating power		
• at AC-1		
— at 230 V at 60 °C Rated value	kW	145
— at 690 V at 60 °C Rated value	kW	430
— at 690 V Rated value	kW	430
• at AC-3		
— at 230 V Rated value	kW	97
— at 400 V Rated value	kW	75

— at 500 V Rated value	kW	90
— at 690 V Rated value	kW	132

Control circuit/ Control:		
Type of voltage of the control supply voltage		AC/DC
Control supply voltage with AC		
• at 50 Hz Rated value	V	110 127
• at 60 Hz Rated value	V	110 127
Control supply voltage for DC		
Rated value	V	110 127
Rated value	Hz	40
Control supply voltage frequency 2 Rated value	Hz	60
Operating range factor control supply voltage rated value of the magnet coil with AC		
● at 50 Hz		0.8 1.1
● at 60 Hz		0.8 1.1
Operating range factor control supply voltage rated value of the magnet coil for DC		0.8 1.1
Design of the surge suppressor		with varistor
Apparent pick-up power of the magnet coil with AC	V·A	590
Apparent holding power of the magnet coil with AC	V·A	6.7
Closing power of the magnet coil for DC	W	650
Holding power of the magnet coil for DC	W	7.4
Inductive power factor		
with closing power of the coil		0.9
 with the holding power of the coil 		0.9
Auxiliary circuit:		
Number of NC contacts		
 for auxiliary contacts 		
 instantaneous contact 		2
Number of NO contacts		
 for auxiliary contacts 		
— instantaneous contact		2
Operating current at AC-15		
• at 230 V Rated value	Α	6
• at 400 V Rated value	Α	3
Operating current		
• at DC-12 at 220 V Rated value	Α	1
• at DC-13 at 220 V Rated value	Α	0.3
Operating current		
● at DC-12		

- at 60 V Rated value

- at 110 V Rated value

6

3

Α

• at DC-13		
— at 24 V Rated value	Α	10
— at 60 V Rated value	Α	2
— at 110 V Rated value	Α	1
— at 110 v Nateu value	, ,	· ·
UL/CSA ratings:		
Contact rating of the auxiliary contacts acc. to UL		A600 / Q600
Short-circuit:		
Design of the fuse link		
 for short-circuit protection of the main circuit 		
 — with type of assignment 1 required 		fuse gL/gG: 500 A
 — with type of assignment 2 required 		fuse gL/gG: 500 A
• for short-circuit protection of the auxiliary switch		fuse gL/gG: 10 A
required		
Installation/ mounting/ dimensions:		
Mounting type		screw fixing
Side-by-side mounting		Yes
Height	mm	210
Width	mm	145
Depth	mm	202
Required spacing		
• for grounded parts		
— at the side	mm	10
Connections/ Terminals:		
Type of electrical connection		
• for main current circuit		screw-type terminals
 for auxiliary and control current circuit 		screw-type terminals
Type of connectable conductor cross-section		
 for AWG conductors for main contacts 		2/0 500 kcmil
• for auxiliary contacts		
— solid		2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²), max. 2x (0.75 4 mm²)
 finely stranded with core end processing 		2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²)
• for AWG conductors for auxiliary contacts		2x (20 16), 2x (18 14), 1x 12
Mechanical data:		
Size of contactor		S10
Ambient conditions: Installation altitude at height above sea level	m	2 000
maximum	m	2 000
Ambient temperature		
during operation	°C	-25 +60
= •		

• during storage °C -55 ... +80

Certificates/ approvals:

General Product Approval Functional Safety/Safety Of Machinery Declaration of Machinery





ABS



DNV



GL

Type Examination

RMRS



Test Certificates	Shipping App	roval		other
Special Test Certificate	OF SHIPPING	<u> †å</u>	[GL	<u>other</u>

other

Confirmation

Environmental Confirmations

Further information

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/industrial-controls/catalogs

Industry Mall (Online ordering system)

http://www.siemens.com/industrymall


Cax online generator


 $\underline{\text{http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en\&mlfb=3RT14666AF36}}$

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

http://support.automation.siemens.com/WW/view/en/3RT14666AF36/all

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...) http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3RT14666AF36&lang=en





3RT106.-.A..6_01_4_IEC.DXF 3RT107.-.A..6_01_4_IEC.DXF

last modified: 11.03.2015