





Declaration of Insulation Transformer No.	AA-58031
Customer:	ELFA AB
Customer Part No:	56-123-04

This transformer is CSA- and UL-Recognized, File No. E115159, according to following standards:

UL1950 & CAN/CSA C22.2 No. 950-95

Standard for safety for Information Technology Equipment, including Electrical Business Equipment.

The construction of this transformer also fulfill the requirements according to IEC 601.1, EN 61558-1, EN 60 950, EN 60 065, UL 2601.1, UL 6500, UL 1411.

Core.

The core is tapewound with cold-rolled grainoriented silicon steel. Core Dimensions: 80x50x20 mm

Core Protection.

The core is insulated with min. four layers of 0,05mm thick Polyesterfilm. UL-Approved under Guide QMFZ2. Flame Class UL 94VTM-2. Approved for 130°C.

Copper Wire.

Polyesterimid enamelled copper wire, according to IEC 317-13. Approved for min. 180°C.

Primary Termination.

Stranded wire: Awg 22 UL-Approved under Guide AVLV2, Style 3266. Approved for 300V and 125°C. Plus an extra insulation tube. UL-Approved under Guide YDPU2. Approved for 105°C.

Secondary Termination.

The wire ends are insulated with insulation tubes. UL-Approved under Guide YDPU2. Approved for 300V and 105°C.

Insulation Primary - Secondary.

The insulation between the primary and the secondary consists of min. four layers of 0,05mm thick Polyester film (total thickness min. 0,2mm). UL-Approved under Guide QMFZ2. Flame Class UL 94VTM-2. Approved for 130°C.

Two of these layers withstands together 4000Vac for one minute. The creep distance exceeds 8mm and the insulation resistanceis more than 5000 Megohm.

Final Insulation.

The outer insulation consists of min. two layers of 0,05mm thick Polyester film. UL-Approved under Guide QMFZ2. Flame Class UL 94VTM-2. Approved for 130°C.

Mounting Hardware.

Washer mounting, consisting of one metal washer and two rubber pads.



EC/EEA Declaration of conformity

Type of equipme	ent: Safety Isolating Tr	Safety Isolating Transformer	
Brand name:	Toroid		
Part no:	AA-58031		
Customer:	ELFA AB	56-123-04	
Manufactures:	Toroid International (Pvt) Ltd PO Box 15, Phase 2, FTZ Katunayake, Sri-Lanka Toroid India Pvt Ltd Technopark Campus Trivandrum 695 581 Kerala, India	Toroid Internation Box 3 351 03 Växjö, Sw Manufacture´s rej within EEA:	veden

As the manufacturer's authorised representative established within EEA, we declare that the product is in conformity with the provision of the EC directives: Low Voltage Directiven (LVD) 73/23/EEG, 93/68/EEG

The product fulfils the requirements according to the following harmonised standards: EN 61558-1, EN 60 950, EN 60 065 and IEC 601-1.

All transformers have been inspected and tested with approved result according to the following:

- 1. Ocular inspection
- 2. No-load input current
- 3. No-load secondary voltage
- 4. Dielectric strength between primary an

The product is to be regarded as a modular component to be used in an electric apparatus that in turn has to fulfil the EMC - directives.

The product itself does not need to be EMC approved for CE marking according to directive 89/336/EEG, 92/31/EEG and 93/68/EEG

Date: 2003-05-07

Thomas Svensson / Design engineer