



Expertise Applied | Answers Delivered

Littelfuse, Inc.
8755 West Higgins Road, Suite 500
Chicago, IL 60631 USA
(773) 628-1000

Subject: TDx Redesign and Rebranding
Document: LFPCN_RC00046
Date Released: July 24, 2020

Dear Valued Customer,

This letter is to inform you of recent changes that have been made to our TDx platform of time delay relays. In an effort to improve manufacturability, Littelfuse has changed from an analog design to a digital design. The digital circuitry allows faster production with higher reliability, accuracy, and quality. Some product series may have experienced minor specification changes related to power consumption or relay ratings, consult with the latest datasheet available on our website. While the internal components of our product have changed, Littelfuse's top priority is to maintain a consistent user interaction with our product.

The complete list of products impacted are:

PRLM41180	TDIL24DL	TDSH120AL
PRLM423	TDM120AL	TDSL120AL
TDB120AL	TDM12DL	TRB120A2Y30
TDB120ALD	TDM230AL	TRB120A3X600
TDB12D	TDM24AL	TRB120A4Y120
TDB230AL	TDM24DL	TRB24D10YT00033
TDB24AL	TDMH120AL	TRM120A2X30
TDB24DL	TDMH24AL	TRM120A2Y120
TDBH120AL	TDML110DL	TRM120A2Y180
TDBH120ALD	TDML120AL	TRM24A8Y5
TDBL120AL	TDML12DL	TRM24D1X10
TDBL120ALD	TDML24DL	TRM24D1X2
TDBL24DL	TDS120AL	TRS120A2X300
TDI120AL	TDS120ALD	TRS120A2Y10
TDI12D	TDS12D	TRS24D7Z10
TDIH24AL	TDS230AL	
TDIL120AL	TDS24AL	

In addition to changes to the circuitry, we have changed the color of some enclosures from black to a Littelfuse green to standardize our product offering. With the change of enclosure, some products may have had dials, indicators, screws and/or switches move locations. The new enclosure is not compatible with the following accessories:

BZ1	NDS-8	PSC8
PSC11		

Finally, These parts continue to have RoHS compliance and maintain their UL and CSA certifications; however, CE labeling has been removed at this time. Please call or email Littelfuse Technical Support at relays@littelfuse.com or 800-832-3873 if you have any questions or concerns about the transition.

Sincerely,

Richard Dale
Associate Product Manager
Industrial Business Unit
Littelfuse, Inc.