SIEMENS

Data sheet 3NJ4121-3BF01



IN-LINE FUSE SWITCH DISCONNECTOR 1-POLE SWITCHABLE, SIZE 1, I=250A , U=690V, SCREW TERMINAL M 10 NEW DESIGN

Figure similar

100 2 000 200 200 200 200 200 200 200 20			
Model			
Product designation	Fuse switch disconnectors		
Design of the product	Mounting onto rail with 185mm busbar center-center spacing		
Type of switching contact / double breaking switching contact	No		
Design of the safety monitoring	No		
Design of the load switch / Strip form	Yes		
Type of the driving mechanism / motor drive	No		
General technical data			
Number of poles	3		
Number of poles / Note	1-pole switchable		

General technical data		
Number of poles		3
Number of poles / Note		1-pole switchable
Type of device		fixed mounting
Size of fuse link		NH1
Continuous current / at 35 °C / Rated value	Α	250
cut-off value I**2t,max. / 500 V	A²-s	780 000
circuit-breaker / Design		3NJ4
Fuse system		LV HRC fuse

Voltage		
Insulation voltage / Rated value	V	1 000
Protection class		
FTOLECTION Class		
Protection class IP / on the front		IP30

Dissipation	
Active power loss	

maximum	W	23

Electricity		
Number of transformers		0
Continuous current		
Rated value	Α	250
● at 40 °C / Rated value	Α	237.5
● at 45 °C / Rated value	Α	225
● at 50 °C / Rated value	Α	212.5
● at 55 °C / Rated value	Α	200
• at 60 °C / Rated value	Α	187.5
● at 65 °C / Rated value	Α	175
● at 70 °C / Rated value	Α	162.5
Let-through current / lc / maximum permissible		
• 400 V	kA	28
• 500V	kA	28
cut-off value I**2t,max. / 400 V	A ² ·s	780 000
Main circuit		
Operating voltage		
• with AC / at 50/60 Hz / Rated value	V	690
● for DC / Rated value	V	440
Operating current		
• at AC-21 B / at 400 V / Rated value	Α	250
• at AC-21 B / at 500 V / Rated value	Α	250
• at AC-21 B / at 690 V / Rated value	Α	250
• at AC-22 B / at 400 V / Rated value	Α	250
• at AC-22 B / at 500 V / Rated value	Α	250
• at AC-22 B / at 690 V / Rated value	Α	200
• at AC-23 B / at 400 V / Rated value	Α	250
Suitability		
Suitability for operation		Plant protection
Suitability for use		
Main switch		No

Suitability		
Suitability for operation	Plant protection	
Suitability for use		
Main switch	No	
 switch disconnector 	Yes	
 EMERGENCY OFF switch 	No	
safety switch	No	
• maintenance/repair switch	No	

Product details		
Product feature / interlock	No	
Product component		
Trip indicator	No	

 Voltage trigger 		No
• undervoltage release		No
 undervoltage release with leading contact 		No
Product expansion		
• optional		
— motor drive		No
— Voltage trigger		No
Short circuit		
Conditional rated short-circuit current / in utilization		
category		
• AC-21 B / at 400 V	kA	110
• AC-21 B / at 500 V	kA	110
• AC-22 B / at 400 V	kA	110
• AC-22 B / at 500 V	kA	110
Connections		
Arrangement of electrical connectors / for main		Screw terminals
current circuit		
Type of electrical connection / for main current circuit		screw-type terminals
Mechanical Design		
Height	mm	662
Width	mm	99.5
Depth	mm	195
mounting position		vertical
Mounting type		Flachanschluss, M 10
Busbar center-to-center spacing	mm	185
Busbar center-to-center spacing		Ma
• 40 mm		No
• 50 mm		No
• 60 mm		No
• 100 mm		No
● 185 mm		Yes
Environmental conditions		
Ambient temperature		
during operation / minimum	°C	-25
during operation / maximum	°C	55
Certificates		
Equipment marking		
• acc. to DIN EN 61346-2		Q
• acc. to DIN EN 81346-2		Q

General Product Approval

Declaration of Conformity

Test Certificates









Special Test Certificate

Further information

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/lowvoltage/catalogs

Industry Mall (Online ordering system)
https://eb.automation.siemens.com/mall/en/WW/Catalog/Product/3NJ41213BF01

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

http://support.automation.siemens.com/WW/view/en/3NJ41213BF01/all

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)

http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3NJ41213BF01

CAx-Online-Generator

http://www.siemens.com/cax

Tender specifications

http://ausschreibungstexte.siemens.com/tiplv

last modified: 11.03.2015