SIEMENS

Data sheet

6GK5202-2BH00-2BA3



SCALANCE X202-2PIRT managed IE IRT switch, 2x 10/100 Mbit/s RJ45 ports, 2x 100 Mbit/s POF SC RJ ports, error signaling contact with set pushbutton, redundant power supply, PROFINET IO device, network management, Redundancy Manager integrated, incl. electron. manual on CD-ROM, C-PLUG optional.

product type designation	SCALANCE X202-2P IRT
transfer rate	
transfer rate	10 Mbit/s, 100 Mbit/s
interfaces / for communication / integrated	
number of electrical connections	
 for network components or terminal equipment 	2
number of 100 Mbit/s SC-RJ-ports / for POF FOC	
 with push-pull connection system 	2
interfaces / other	
number of electrical connections	
 for signaling contact 	1
for power supply	1
type of electrical connection	
 for signaling contact 	2-pole terminal block
 for power supply 	4-pole terminal block
design of the removable storage	
• C-PLUG	Yes
signal inputs/outputs	
operating voltage / of the signaling contacts	
at DC / rated value	24 V
operational current / of the signaling contacts	
• at DC / maximum	0.1 A
supply voltage, current consumption, power loss	
product component / connection for redundant voltage supply	Yes
type of voltage / 1 / of the supply voltage	DC
 supply voltage / 1 / rated value 	24 V
 power loss [W] / 1 / rated value 	7.2 W
 supply voltage / 1 / rated value 	18 32 V
 consumed current / 1 / maximum 	0.3 A
 type of electrical connection / 1 / for power supply 	4-pole terminal block
 product component / 1 / fusing at power supply input 	Yes
fuse protection type / 1 / at input for supply voltage	1.1 A / 33 V
ambient conditions	
ambient temperature	
 during operation 	-25 +60 °C
during storage	-40 +70 °C
during transport	-40 +70 °C
relative humidity	

 at 25 °C / without condensation / during operation / maximum 	95 %
protection class IP	IP30
design, dimensions and weights	
design	compact
width	60 mm
	125 mm
height	124 mm
depth	
net weight	0.78 kg
5	Yes
35 mm top hat DIN rail mounting	Yes
wall mounting	Yes
S7-300 rail mounting S7 1500 rail mounting	No
• S7-1500 rail mounting	
product features, product functions, product components	
cascading in the case of a redundant ring / at reconfiguration time of <\~0.3\~s	50
cascading in cases of star topology	any (depending only on signal propagation time)
product functions / management, configuration, engineer	
product function	
• CLI	Yes
web-based management	Yes
MIB support	Yes
TRAPs via email	Yes
configuration with STEP 7	Yes
port mirroring	No
multiport mirroring	No
with IRT / PROFINET IO switch	Yes
PROFINET IO diagnosis	Yes
PROFINET conformity class	C
network load class / according to PROFINET	2
product function / switch-managed	Yes
protocol / is supported	
Telnet	Yes
• HTTP	Yes
• HTTPS	Yes
• TFTP	Yes
• FTP	Yes
• BOOTP	No
• DCP	Yes
• LLDP	Yes
• SNMP v1	Yes
• SNMP v1 • SNMP v2	Yes
• SNMP V2 • SNMP V3	Yes
identification & maintenance function	
I&M0 - device-specific information	Yes
I&M1 – higher level designation/location designation	Yes
product functions / diagnostics	
product function	Yes
 port diagnostics statistics Packet Size 	Yes
	Yes
statistics packet type	
error statistics	Yes
product functions / DHCP	
product function	Vec
DHCP client	Yes
product functions / redundancy	
product function	
• ring redundancy	Yes
 High Speed Redundancy Protocol (HRP) 	Yes

 high speed redundancy protocol (HRP) with 	Yes
redundancy manager	
 high speed redundancy protocol (HRP) with standby redundancy 	Yes
protocol / is supported / Media Redundancy Protocol	Yes
(MRP)	
product function	
 media redundancy protocol (MRP) with redundancy 	Yes
manager	
 Media Redundancy Protocol for Planned Duplication (MRPD) 	Yes
Parallel Redundancy Protocol (PRP)/operation in	Yes
the PRP-network	
 Parallel Redundancy Protocol (PRP)/Redundant 	No
Network Access (RNA)	
passive listening	Yes
product functions / security	
protocol / is supported	
• SSH	Yes
product functions / time	
product function	
SICLOCK support	Yes
protocol / is supported	
• NTP	No
• SNTP	Yes
standards, specifications, approvals	
standard	
• for FM	FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP.
- for opfaty / from CCA and III	IIC, T4
 for safety / from CSA and UL for amitted interference 	UL 60950-1, CSA C22.2 No. 60950-1
for emitted interference for interference immunity	EN 61000-6-4:2001 (Class A) EN 61000-6-4:2001
for interference immunity MTBF	
reference code	83.72 y
according to IEC 81346-2	
according to IEC 81346-2	KF
• according to IEC 81346-2:2019	KF KFE
according to IEC 81346-2:2019 standards, specifications, approvals / CE	KFE
according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking	KFE Yes
according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environment	KFE Yes nents
according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking	KFE Yes nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07
according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environment	KFE Yes nents
according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone	KFE Yes nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X
according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone	KFE Yes nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A,
according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environ standard / for hazardous zone from CSA and UL	KFE Yes nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A,
e according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone e from CSA and UL certificate of suitability e CCC / for hazardous zone according to GB standard e for cULus HazLoc / as File Nr.	KFE Yes EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4
e according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone e from CSA and UL certificate of suitability e CCC / for hazardous zone according to GB standard	KFE Yes EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes
according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard for cULus HazLoc / as File Nr.	KFE Yes EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes
eaccording to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environe standard / for hazardous zone e from CSA and UL certificate of suitability e CCC / for hazardous zone according to GB standard e for cULus HazLoc / as File Nr. standards, specifications, approvals / other	KFE Yes nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7)
according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environ standard / for hazardous zone from CSA and UL certificate of suitability	KFE Yes nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001
according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone e from CSA and UL certificate of suitability e CCC / for hazardous zone according to GB standard e for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability e C-Tick	KFE Yes nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes
according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval	KFE Yes nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes
e according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone e from CSA and UL certificate of suitability e CCC / for hazardous zone according to GB standard e for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability e C-Tick e KC approval e railway application in accordance with EN 50155	KFE Yes nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes No
 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environer standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability C-Tick KC approval railway application in accordance with EN 50155 railway application in accordance with EN 50124-1 	KFE Yes nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes No
 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environr standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability C-Tick KC approval railway application in accordance with EN 50155 railway application in accordance with EN 50124-1 	KFE Yes nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes No No
 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environer standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability CCC / for hazardous zone according to GB standard for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability C-Tick KC approval railway application in accordance with EN 50155 railway application in accordance with EN 50124-1 accessories product extension / optional / C-PLUG 	KFE Yes nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes No No
 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environr standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability CCC / for hazardous zone according to GB standard for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability C-Tick KC approval railway application in accordance with EN 50155 railway application in accordance with EN 50124-1 accessories product extension / optional / C-PLUG further information / internet-Links 	KFE Yes nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes No No
 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environer standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability CCC / for hazardous zone according to GB standard for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability C-Tick KC approval railway application in accordance with EN 50155 railway application in accordance with EN 50124-1 accessories product extension / optional / C-PLUG further information / internet-Links 	KFE Yes nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes
 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environer standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability C-Tick KC approval railway application in accordance with EN 50155 railway application in accordance with EN 50124-1 accessories product extension / optional / C-PLUG further information / internet-Links Internet-Link to web page: selection aid TIA Selection Tool 	KFE Yes nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes Yes No No No No Yes Yes
 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environer standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability CCC / for hazardous zone according to GB standard for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability C-Tick KC approval railway application in accordance with EN 50155 railway application in accordance with EN 50124-1 accessories product extension / optional / C-PLUG further information / internet-Links Internet-Link to web page: selection aid TIA Selection Tool to website: Industrial communication 	KFE Yes nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes Yes No No No No No No No No Yes
 according to IEC 81346-2:2019 standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environe standard / for hazardous zone from CSA and UL certificate of suitability CCC / for hazardous zone according to GB standard for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability CCC / for hazardous zone according to GB standard for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability C-Tick KC approval railway application in accordance with EN 50155 railway application in accordance with EN 50124-1 accessories product extension / optional / C-PLUG further information / internet-Links Internet-Link to web page: selection aid TIA Selection Tool to website: Industrial communication to website: Industry Mall 	KFE Yes nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes http://www.siemens.com/tia-selection-tool http://www.siemens.com/simatic-net http://mall.industry.siemens.com

• to website: CAx-Download-Manager http://www.siemens.com/cax • to website: Industry Online Support https://support.industry.siemens.com security information Siemens provides products and solutions with industrial security security information functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action (e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security concept. Third-party products that may be in use should also be considered. For more information about industrial security, visit http://www.siemens.com/industrialsecurity. To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit http://support.automation.siemens.com.

2/8/2022 🖸

(V3.4)