

# RCD/MCB combination switch, 25A, 30mA, C-LS-Char, 3N pole, FI-Char: A

Powering Business Worldwide\*

Part no. mRB4-25/3N/C/003-A Article no. 120678

Similar to illustration

		IIV	$\alpha rv$	nrc	nara	mme
u	C	IΙV	CI V	pit	yyıa	

			0 1: 1000/4400 1 :
Basic function			Combined RCD/MCB devices
Pole			3 pole+N
Tripping characteristic			C
Rated current	In	Α	25
Rated switching capacity acc. to IEC/EN 60947-2		kA	4.5
Rated switching capacity according to IEC/EN 61009		kA	4.5
Rated fault current	$I_{\Delta N}$	Α	0.03
Tripping		Α	non-delayed
Product range			mRB4
Sensitivity			AC and pulsating DC current sensitive
Impulse withstand current			Partly surge-proof 250 A
Contact sequence			T H H

### **Technical data**

#### Electrical

A non-delayed lated operating voltage lated frequency lated				
Ue VAC 230/400 lated frequency f Hz 50 lated frequency IΔn mA 30, 100, 300 lated non-tripping current IΔn μα	Standards			IEC/EN 61009
Interdiffequency Interd	Tripping		Α	non-delayed
Ideal fault currents  Ideal fault current	Rated operating voltage	U <sub>e</sub>	V AC	230/400
lated non-tripping current lated non-tripping current lated non-tripping current lated switching capacity lated current lated current lated current lated impulse withstand voltage lated current lated current lated current lated current lated current lated current lated with pulsed current lated scale current lated with pulsed current lated with pulsed current lated scale current lated with pulsed current lated with pul	Rated frequency	f	Hz	50
Lensitivity Lensit	Rated fault currents	$I_{\Delta n}$	mA	30, 100, 300
lated switching capacity lated current leted current leted impulse withstand voltage lited imp	Rated non-tripping current	IΔno		0.5 x l △n
I e A G - 25 I ated impulse withstand voltage I haracteristic I havinum max. as short-circuit protective device I electricial I e A G - 25 I (1.2/50 µs) I (	Sensitivity			DC and pulsed current
tated impulse withstand voltage  Vimp  kV  4 (1.2/50 µs)  C, D  Aximum max. as short-circuit protective device  AgL  100  1electivity Class  S  Electrical  Mechanical  Operations 20000	Rated switching capacity	I <sub>cn</sub>	kA	4.5
C, D  Maximum max. as short-circuit protective device  A gL  100  electivity Class  ifespan  Electrical  Mechanical  Operations 20000	Rated current	I <sub>e</sub>	Α	6 - 25
AgL 100 delectivity Class 3  Electrical Operations 4000  Mechanical Operations 20000	Rated impulse withstand voltage	$U_{\text{imp}}$	kV	4 (1.2/50 µs)
lelectivity Class sifespan S Electrical Mechanical Operations 20000	Characteristic			C, D
lelectivity Class sifespan S Electrical Mechanical Operations 20000				
ifespan S  Electrical Operations 4000  Mechanical Operations 20000	Maximum max. as short-circuit protective device		A gL	100
Electrical Operations 4000  Mechanical Operations 20000	Selectivity Class			3
Mechanical Operations 20000	Lifespan		S	
	Electrical		Operation	ns 4000
lechanical			Operation	ns 20000
	Mechanical			

Standard front dimension	mm	45
Enclosure height	mm	80
Terminal protection		Busbar tag shroud to VBG4
Mounting width	mm	70 (4 SU)
Mounting		Tristable slide catch enables removal from existing combination.
Degree of protection		
Switch		IP20
Integrated		IP40
Terminals top and bottom		Twin-purpose terminals
Terminal capacities	$mm^2$	

Solid	$\text{mm}^2$	1 - 25
Thickness of busbar material	mm	0.8 2
Admissible ambient temperature range	°C	-25 +40
Climatic proofing		according to IEC 68-2 (25 - 55 °C, 90 - 95 % Humidity)

# Design verification as per IEC/EN 61439

Design vermounds per 120/211 01-103			
Technical data for design verification			
Rated operational current for specified heat dissipation	In	Α	25
Heat dissipation per pole, current-dependent	P <sub>vid</sub>	W	0
Equipment heat dissipation, current-dependent	P <sub>vid</sub>	W	11.6
Static heat dissipation, non-current-dependent	P <sub>vs</sub>	W	0
Heat dissipation capacity	P <sub>diss</sub>	W	0
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	40
			0
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:constraint}$
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

### **Technical data ETIM 6.0**


Circuit breakers and fuses (EG000020) / Earth leakage circuit breaker (EC000905)

Electric engineering, automation, process control engineering / Electrical installation, device / Residual current protection system / MCB/RCCB combination (ecl@ss8.1-27-14-22-07 [AFZ810012])

[AFZ810012])		
Number of poles (total)		4
Number of protected poles		1
Nominal rated voltage	V	400
Nominal rated current	Α	25
Rated fault current	Α	0.03
Leakage current type		A
Current limiting class		3
Rated short-circuit breaking capacity EN 60898	kA	4.5

Rated short-circuit breaking capacity IEC 60947-2	kA	0
Frequency		50 Hz
Release characteristic		C
Concurrently switching N-neutral		Yes
Over voltage category		3
Pollution degree		2
Width in number of modular spacings		4
Built-in depth	mm	70
Suitable for flush-mounted installation		No
Degree of protection (IP)		IP20
Surge current capacity	kA	0.25
Voltage type		AC
Antinuisance tripping version		No

#### **Characteristics**



# **Dimensions**

