





CE







Model Number

OBT300-R101-2EP-IO-0,3M-V1-L

Triangulation sensor (BGS) with fixed cable and M12 connector, 4-pin

Features

- Miniature design with versatile mounting options
- DuraBeam Laser Sensors durable and employable like an LED
- Extended temperature range -40°C ... 60°C
- · High degree of protection IP69K
- IO-link interface for service and process data


Product information

The miniature optical sensors are the first devices of their kind to offer an end-to- end solution in a small single standard design — from thru-beam sensor through to a distance measurement device. As a result of this design, the sensors are able to perform practically all standard automation tasks.


The DuraBeam laser sensors are durable and can be used in the same way as a standard sensor.

The use of Multi Pixel Technology gives the standard sensors a high level of flexibility and enables them to adapt more effectively to their operating environment.

Dimensions



Electrical connection




Pinout



Wire colors in accordance with EN 60947-5-2

1 | BN (brown 2 | WH (white) 3 | BU (blue) 4 | BK (black)

Indicators/operating means



- Light-on/dark-on changeover switch
- 2 Sensing range adjuster
- 3 Operating indicator / dark on
- 4 Signal indicator
- 5 Operating indicator / light on

Technical data

General specifications

7 ... 300 mm Detection range Detection range min. 7 ... 25 mm Detection range max 7 ... 300 mm Adjustment range 25 ... 300 mm

Reference target standard white, 100 mm x 100 mm

Light source laser diode

Light type modulated visible red light

Laser nominal ratings

Note LASER LIGHT, DO NOT STARE INTO BEAM

Laser class Wave length

Beam divergence > 5 mrad d63 < 1 mm in the range of 150 mm ... 250 mm

Pulse length 3 µs

Repetition rate approx. 13 kHz max. pulse energy 10.4 nJ Black/White difference (6 %/90 %) < 5 % at 150 mm

Diameter of the light spot approx. 1 mm at a distance of 200 mm

Angle of divergence approx. 0.3°

EN 60947-5-2: 40000 Lux Ambient light limit

Functional safety related parameters

 $MTTF_d$ 560 a Mission Time (T_M) 20 a Diagnostic Coverage (DC) 0 %

Indicators/operating means

Operation indicator LED green:

constantly on - power on flashing (4Hz) - short circuit

flashing with short break (1 Hz) - IO-Link mode

Function indicator

constantly on - object detected constantly off - object not detected Light-on/dark-on changeover switch

Control elements Sensing range adjuster

Electrical specifications

Control elements

Operating voltage 10 ... 30 V DC U_B Ripple max. 10 %

No-load supply current I_0 < 20 mA at 24 V supply voltage

Protection class

Interface

IO-Link (via C/Q = pin 4) Interface type Device profile COM 2 (38.4 kBaud) Transfer rate **IO-Link Revision** 1.1

Min. cycle time 2.3 ms Process data witdh Process data input 1 Bit

Process data output 2 Bit SIO mode support

Device ID 0x110602 (1115650)

Compatible master port type

Output

Switching type The switching type of the sensor is adjustable. The default

C/Q - Pin4: NPN normally open / light-on, PNP normally closed /

/Q - Pin2: NPN normally closed / dark-on, PNP normally open /

Signal output 2 push-pull (4 in 1)outputs, short-circuit protected, reverse

polarity protected, overvoltage protected

Switching voltage max, 30 V DC

max. 100 mA, resistive load Switching current DC-12 and DC-13 Usage category

Voltage drop U_d ≤ 1.5 V DC 1650 Hz Switching frequency Response time 300 μs

Conformity

Communication interface IEC 61131-9 Product standard EN 60947-5-2 Laser safety EN 60825-1:2014

Ambient conditions

Ambient temperature -40 ... 60 °C (-40 ... 140 °F) , fixed cable

-25 ... 60 °C (-13 ... 140 °F) , movable cable not appropriate for

conveyor chains

-40 ... 70 °C (-40 ... 158 °F) Storage temperature

Mechanical specifications

Housing width 13.9 mm

Laserlabel



CLASS 1 LASER PRODUCT

IEC 60825-1: 2007 certified. Complies with 21 CFR 1040.10 and 1040.11 except for deviations pursuant to Laser Notice No. 50. dated June 24, 2007

CLASS 1 LASER PRODUCT

IEC 60825-1: 2007 certified. Complies with 21 CFR 1040.10 and 1040.11 except for deviations pursuant to Laser Notice No. 50, dated June 24, 2007

Accessories

IO-Link-Master02-USB

IO-Link master, supply via USB port or separate power supply, LED indicators, M12 plug for sensor connection

V1-G-2M-PUR

Female cordset, M12, 4-pin, PUR cable

V1-W-2M-PUR

Female cordset, M12, 4-pin, PUR cable

OMH-R101

Mounting Clamp

OMH-R101-Front

Mounting Clamp

OMH-4.1

Mounting Clamp

OMH-ML6

Mounting bracket

OMH-ML6-U

Mounting bracket

OMH-ML6-Z

Mounting bracket

V31-GM-2M-PUR

Female cordset, M8, 4-pin, PUR cable

V31-WM-2M-PUR


Female cordset, M8, 4-pin, PUR cable


Other suitable accessories can be found at www.pepperl-fuchs.com


267075-0107_eng.xml 2019-03-26 issne: Release date: 2019-03-26 09:35

Housing height	33.8 mm
Housing depth	18.3 mm
Degree of protection	IP67 / IP69 / IP69K
Connection	300 mm fixed cable with M12 x 1, 4-pin connector
Material	
Housing	PC (Polycarbonate)
Optical face	PMMA
Mass	approx. 17 g
Cable length	0.3 m
Approvals and certificates	
UL approval	E87056, cULus Listed, class 2 power supply, type rating 1
FDA approval	IEC 60825-1:2007 Complies with 21 CFR 1040.10 and 1040.11 except for deviations pursuant to Laser Notice No. 50, dated June 24, 2007


Curves/Diagrams







Functions and Operation



- 1 Light-on / dark-on changeover switch
- 2 Sensing range /sensitivity adjuster
- 3 Operating indicator / dark on
- 4 Signal indicator
- 5 Operating indicator / light on

To unlock the adjustment functions turn the sensing range adjuster for more than 180 degrees.

Sensing Range / Sensitivity

Turn sensing range / sensivity adjuster clockwise to increase sensing range / sensitivity.

Turn sensing range /sensivity adjuster counter clockwise to decrease sensing range / sensitivity.

If the end of the adjustment range is reached, the signal indicator starts flashing with 8 Hz.

Light-on / Dark-on Configuration

Press the light-on / dark-on changeover switch for more than 1 second (less than 4 seconds). The light-on / dark-on mode changes and the operating indicators are activated accordingly.

If you press the light-on / dark-on changeover switch for more than 4 seconds, the light-on / dark-on mode changes back to the original setting. On release of the light-on / dark-on changeover switch the current state is activated.

Restore Factory Settings

Press the light-on / dark-on changeover switch for more than 10 seconds (less than 30 seconds) until all LEDs turn off. On release of the light-on / dark-on changeover switch the signal indicator turns on. After 5 seconds the sensor resumes operation with factory default settings.

After 5 minutes of inactivity the sensing range / sensivity adjustment is locked. In order to reactivate the sensing range / sensivity adjustment, turn the sensing range / sensivity adjuster for more than 180 degrees.