SIEMENS

Data sheet 3KD4840-0QE10-0

SWITCH-DISCONNECTOR 800A, FRAME SIZE 4, 4-POLE FRONT OPERATING LEFT BASIC UNIT WITHOUT HANDLE FLAT TERMINAL



| Model | | |
|--|----|--------------------------|
| product brand name | | SENTRON |
| Product designation | | Switching device |
| Design of the product | | 3KD switch disconnectors |
| Design of the operating mechanism | | without |
| Design of handle | | without |
| Type of the driving mechanism / motor drive | | No |
| General technical data | | |
| Number of poles | | 4 |
| Type of device | | fixed mounting |
| circuit-breaker / Design | | 3KD4 |
| Mechanical service life (switching cycles) / typical | | 8 000 |
| Overvoltage category | | IV |
| Voltage | | |
| Insulation voltage / Rated value | V | 1 000 |
| Surge voltage resistance / Rated value | kV | 12 |
| Protection class | | |
| Protection class IP | | IP00 |
| Protection class IP / on the front | | IP00 |
| Dissipation | | |
| Active power loss | | |
| with conventional rated thermal current / per pole | W | 35 |

| Electricity | | |
|--|----|-----|
| Continuous current | | |
| Rated value | Α | 800 |
| • at 40 °C / Rated value | Α | 800 |
| • at 45 °C / Rated value | Α | 800 |
| • at 50 °C / Rated value | Α | 800 |
| • at 55 °C / Rated value | Α | 800 |
| • at 60 °C / Rated value | Α | 630 |
| • at 65 °C / Rated value | Α | 630 |
| • at 70 °C / Rated value | Α | 630 |
| Short-time current resistance (Icw) / limited to 1 s / Rated value | kA | 30 |
| Main circuit | | |
| Operating power | | |
| ● at AC-23 A / at 400 V / at 50/60 Hz / Rated value | kW | 355 |
| • at AC-23 A / at 500 V / at 50/60 Hz / Rated value | kW | 400 |
| • at AC-23 A / at 690 V / at 50/60 Hz / Rated value | kW | 500 |
| Operating voltage | | |
| • with AC / at 50/60 Hz / Rated value | V | 690 |
| Auxiliary circuit | | |
| Number of CO contacts / for auxiliary contacts | | 0 |
| Number of NC contacts / for auxiliary contacts | | 8 |
| Number of NO contacts / for auxiliary contacts | | 8 |
| Suitability | | |
| Suitability for use | | |
| Main switch | | Yes |
| switch disconnector | | Yes |
| EMERGENCY OFF switch | | No |
| safety switch | | Yes |
| • maintenance/repair switch | | Yes |
| Product details | | |
| Product feature / interlock | | No |
| Product component | | Ne |
| Trip indicator | | No |
| Voltage trigger | | No |
| undervoltage release | | No |
| undervoltage release with leading contact | | No |
| Product expansion | | |

| Auxiliary switch | Yes | |
|-------------------|-----|--|
| • optional | | |
| — motor drive | No | |
| — Voltage trigger | No | |

| Connections | |
|-------------------------------|----------------|
| Type of electrical connection | |
| • for main current circuit | flat connector |

| Mechanical Design | | |
|--|----|----------------|
| Height | mm | 235 |
| Width | mm | 320 |
| Depth | mm | 110 |
| mounting position | | any |
| Mounting type | | floor mounting |
| Mounting type | | |
| front mounting with 4-hole attachment | | No |
| front mounting with central attachment | | No |
| • rail mounting | | No |

| Environmental conditions | | | |
|--|----|-----|--|
| Ambient temperature | | | |
| during operation / minimum | °C | -25 | |
| during operation / maximum | °C | 70 | |
| during storage / minimum | °C | -50 | |
| during storage / maximum | °C | 80 | |

| Certificates | | |
|--|---|--|
| Equipment marking / acc. to DIN EN 61346-2 | Q | |

General Product Approval

Declaration of Conformity









Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/lowvoltage/catalogs

Industry Mall (Online ordering system)
https://eb.automation.siemens.com/mall/en/WW/Catalog/Product/3KD48400QE100


Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

http://support.automation.siemens.com/WW/view/en/3KD48400QE100/all

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...) http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3KD48400QE100

CAx-Online-Generator

http://www.siemens.com/cax



last modified: 11.03.2015