# **SIEMENS**

Data sheet 3RT1076-6AD36



CONTACTOR, 250KW/400V/AC-3 AC(40...60HZ)/DC OPERATION UC 42-48V AUXILIARY CONTACTS 2NO+2NC 3-POLE, SIZE S12 BAR CONNECTIONS CONVENT. OPERATING MECHANISM SCREW TERMINAL

Figure similar

product brand name	SIRIUS
Product designation	power contactor

V	1 000
	3
kV	8
	10 000 000
	5 000 000
	10 000 000
Α	4 000
	IP00
	IP00
	Q
	Q
	kV

Main circuit:	
Number of poles for main current circuit	3
Number of NC contacts for main contacts	0
Number of NO contacts for main contacts	3
Operating current	

● at AC-1		
— at 400 V at ambient temperature 40 °C	Α	610
Rated value		
— up to 690 V at ambient temperature 40 °C	Α	610
Rated value		
— up to 690 V at ambient temperature 60 $^{\circ}\text{C}$	Α	550
Rated value		
• at AC-3		
— at 400 V Rated value	Α	500
— at 690 V Rated value	Α	450
• at AC-4 at 400 V Rated value	Α	430
Operating current with 1 current path		
• at DC-1		
— at 24 V Rated value	Α	400
— at 110 V Rated value	Α	33
• at DC-3 at DC-5		
— at 24 V Rated value	Α	400
— at 110 V Rated value	Α	3
Operating current with 2 current paths in series		
● at DC-1		
— at 24 V Rated value	Α	400
— at 110 V Rated value	Α	400
• at DC-3 at DC-5		
— at 110 V Rated value	Α	400
— at 24 V Rated value	Α	400
Operating current with 3 current paths in series		
● at DC-1		
— at 24 V Rated value	Α	400
— at 110 V Rated value	Α	400
• at DC-3 at DC-5		
— at 110 V Rated value	Α	400
— at 24 V Rated value	Α	400
Operating power		
● at AC-1 at 400 V Rated value	kW	362
• at AC-2 at 400 V Rated value	kW	291
• at AC-4 at 400 V Rated value	W	250 000
Operating power		
• at AC-1		
— at 230 V at 60 °C Rated value	kW	151
— at 690 V at 60 °C Rated value	kW	624
— at 690 V Rated value	kW	624
• at AC-3		

— at 230 V Rated value	kW	164
— at 400 V Rated value	kW	291
— at 500 V Rated value	kW	363
— at 690 V Rated value	kW	453
Operating power for ≥ 200000 operating cycles at		
AC-4		
● at 400 V Rated value	kW	98
• at 690 V Rated value	kW	148
Operating frequency		
• at AC-3 maximum	1/h	420

Control circuit/ Control:			
Type of voltage of the control supply voltage		AC/DC	
Control supply voltage with AC			
● at 50 Hz Rated value	V	42 48	
● at 60 Hz Rated value	V	42 48	
Control supply voltage for DC			
Rated value	V	42 48	
Rated value	Hz	40	
Control supply voltage frequency 2 Rated value	Hz	60	
Operating range factor control supply voltage rated			
value of the magnet coil with AC			
● at 50 Hz		0.8 1.1	
● at 60 Hz		0.8 1.1	
Operating range factor control supply voltage rated		0.8 1.1	
value of the magnet coil for DC			
Design of the surge suppressor		with varistor	
Apparent pick-up power of the magnet coil with AC	V·A	830	
Apparent holding power of the magnet coil with AC	V·A	9.2	
Closing power of the magnet coil for DC	W	920	
Holding power of the magnet coil for DC	W	10	
Inductive power factor			
<ul><li>with closing power of the coil</li></ul>		0.9	
<ul> <li>with the holding power of the coil</li> </ul>		0.9	

Auxiliary circuit:		
Number of NC contacts		
<ul> <li>for auxiliary contacts</li> </ul>		
— instantaneous contact		2
Number of NO contacts		
<ul> <li>for auxiliary contacts</li> </ul>		
— instantaneous contact		2
Operating current at AC-15		
• at 230 V Rated value	Α	6

● at 400 V Rated value	Α	3
Operating current		
• at DC-12 at 220 V Rated value	Α	1
• at DC-13 at 220 V Rated value	Α	0.3
Operating current		
• at DC-12		
— at 60 V Rated value	Α	6
— at 110 V Rated value	Α	3
• at DC-13		
— at 24 V Rated value	Α	10
— at 60 V Rated value	Α	2
— at 110 V Rated value	Α	1
UL/CSA ratings:		
Contact rating of the auxiliary contacts acc. to UL		A600 / Q600
Short-circuit:		
Design of the fuse link		
• for short-circuit protection of the main circuit		
<ul> <li>— with type of assignment 1 required</li> </ul>		fuse gL/gG: 630 A
<ul> <li>— with type of assignment 2 required</li> </ul>		fuse gL/gG: 500 A
• for short-circuit protection of the auxiliary switch		fuse gL/gG: 10 A
required		
Installation/ mounting/ dimensions:		
Mounting type		screw fixing
<ul> <li>Side-by-side mounting</li> </ul>		Yes
Height	mm	214
Width	mm	160
Depth	mm	225
Required spacing		
<ul><li>for grounded parts</li></ul>		
— at the side	mm	10
Connections/ Terminals:		
Type of electrical connection		
• for main current circuit		screw-type terminals
<ul> <li>for auxiliary and control current circuit</li> </ul>		screw-type terminals
Type of connectable conductor cross-section		
<ul> <li>for AWG conductors for main contacts</li> </ul>		2/0 500 kcmil
• for auxiliary contacts		
— solid		2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²), max. 2x
		(0.75 4 mm²)
<ul> <li>finely stranded with core end processing</li> </ul>		2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²)
• for AWG conductors for auxiliary contacts		2x (20 16), 2x (18 14), 1x 12

Mechanical data:		
Size of contactor		S12
Ambient conditions:		
Installation altitude at height above sea level	m	2 000
maximum		
Ambient temperature		
<ul><li>during operation</li></ul>	°C	-25 <b>+</b> 60
during storage	°C	-55 <b>+</b> 80

### Certificates/ approvals:

General Product Approval	Functional	Declaration of
	Safety/Safety	Conformity
	of Machinery	









Type Examination



#### **Test Certificates**

## **Shipping Approval**

Type Test
Certificates/Test
Report

Special Test Certificate











### other

<u>Confirmation</u> <u>Environmental</u> <u>other</u> <u>Confirmations</u>

### Further information

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/industrial-controls/catalogs

Industry Mall (Online ordering system)

http://www.siemens.com/industrymall


Cax online generator


 $\underline{\text{http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en\&mlfb=3RT10766AD36}$ 

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

 $\underline{\text{http://support.automation.siemens.com/WW/view/en/3RT10766AD36/all}}$ 

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...) http://www.automation.siemens.com/bilddb/cax\_de.aspx?mlfb=3RT10766AD36&lang=en





3RT106.-.A..6\_01\_4\_IEC.DXF 3RT107.-.A..6\_01\_4\_IEC.DXF

last modified:

11.03.2015