

Residual current circuit breaker (RCCB), 63A, 2p, 300mA, type G/F

Powering Business Worldwide*

Part no. PFIM-63/2/03-G/F Article no. 187454

Similar to illustration

De	livery	v nro	aran	ıme

		Residual current circuit breakers
		2 pole
		Switchgear for residential and commercial applications
In	Α	63
I _{cn}	kA	10 with back-up fuse
$I_{\Delta N}$	Α	0.3
		Typ G/F (ÖVE E 8601)
	Α	Short time-delayed
		PFIM-F
		pulse-current sensitive - frequency composition (10 Hz, 50 Hz, 1000 Hz)
		surge-proof 5 kA
	I _{cn}	I _{cn} kA I _{ΔN} A

Technical data

Electrical

Types conform to			IEC/EN 62423
Current test marks			As per inscription
Rated operating voltage	Un	V AC	230
Rated frequency	f	Hz	50
Limit values of the operating voltage			
Test circuit		V AC	196 - 264
Rated frequency	f	Hz	50
Sensitivity			pulse-current sensitive - frequency composition (10 Hz, 50 Hz, 1000 Hz)
Rated insulation voltage	Ui	V	440
Rated impulse withstand voltage	U_{imp}	kV	4 (1.2/50μs)
Rated short-circuit strength	I _{cn}	kA	10 with back-up fuse
Max. admissible back-up fuse			
Short-circuit	gG/gL	Α	63
Overload	gG/gL	Α	40
Rated making and breaking capacity / Rated residual making and breaking capacity	$I_m/I_{\Delta m}$	Α	630
lifespan			
Electrical			ons== 2000
Mechanical		Operation	on≦≥ 10000
Mechanical			

Wechanical		
Standard front dimension	mm	45
Device height	mm	80
Built-in width	mm	35 (2TE)
Mounting		Quick attachment with 2 latch positions for DIN-rail IEC/EN 60715
Degree of Protection		IP20 switches IP 40 enclosed
Terminals top and bottom		Twin-purpose terminals
Terminal protection		Busbar tag shroud to BGV A3, ÖVE-EN 6
Terminal cross-section		
Solid	mm ²	1.5 - 35

Stranded	mm ²	2 x 16
Terminal cross-section		M5 (with cross-recessed screw as defined in EN ISO 4757-Z2, Pozidriv PZ2)
Tightening torque of fixing screws	N/m	2 - 2.4
Thickness of busbar material	mm	0.8 - 2
Admissible ambient temperature range	°C	-25 - +40
Permissible storage and transport temperatures	°C	-35 - +60
Climatic proofing		according to IEC/EN 61008
Mounting position		As required
Contact position indicator		red / green

Design verification as per IEC/EN 61439

Technical data for design verification			
Rated operational current for specified heat dissipation	In	Α	63
Equipment heat dissipation, current-dependent	P _{vid}	W	13.5
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 6.0

Circuit breakers and fuses (EG000020) / Residual current circuit breaker (RCCB) (EC000003)			
Electric engineering, automation, process control engineering / Electrical installation, device / Residual current protection system / Residual current circuit breaker (RCCB) (ecl@ss8.1-27-14-22-01 [AAB906011])			
Number of poles			2
Nominal rated voltage	V	/	230
Nominal rated current	Д	A	63
Rated fault current	Д	A	0.3
Mounting method			DIN rail
Leakage current type			-
Selective protection			No
Short-circuit breaking capacity (Icw)	k	κA	10
Surge current capacity	k	κA	3

Frequency		50 Hz
Additional equipment possible		Yes
Degree of protection (IP)		IP20
Construction size (in accordance with DIN 43880)		1
Width in number of modular spacings		2
Built-in depth	mm	70.5
Short-time delayed tripping		Yes