SIEMENS

Data sheet 3LD2830-0TK11



MAIN CONTROL SWITCH 3-POLE IU=125, P/AC-23A AT 400V=45KW BASE MOUNTING MOUNTING RAIL/TWO-HOLE MOUNTING KNOB BLACK

Model			
product brand name		SENTRON	
Product designation		Main and EMERGENCY-STOP switches	
Design of the operating mechanism		knob-operated mechanism, black	
Type of the driving mechanism / motor drive		No	
General technical data			
Number of poles		3	
Type of device		fixed mounting	
Protection against electrical shock		finger-safe	
Mechanical service life (switching cycles) / of the main contacts / typical		100 000	
Operating frequency / maximum	1/h	50	
Voltage			
Insulation voltage / Rated value	V	690	
Surge voltage resistance / Rated value	V	6 000	
Protection class			
Protection class IP		IP44	
Electricity			
Continuous current / Rated value	Α	125	
Short-time current resistance (Icw) / at 690 V / limited to 1 s / Rated value	Α	2 000	
Main circuit			
Operating frequency			
● initial value	Hz	50	

Full-scale value	Hz	60
Operating power		
• at AC-23 A / at 400 V / Rated value	kW	45
• at AC-23 A / at 690 V / Rated value	kW	37
• at AC-3 / at 400 V / Rated value	kW	37
• at AC-3 / at 690 V / Rated value	kW	30
Operating voltage		
• with AC / at 50/60 Hz / Rated value	V	690
Operating current / at AC-21 / Rated value	Α	125
Auxiliary circuit		
Number of CO contacts / for auxiliary contacts		0
Number of NC contacts / for auxiliary contacts		0
Number of NO contacts / for auxiliary contacts		0
Operating voltage / of the auxiliary contacts / with AC / maximum	V	500
Continuous current / of the auxiliary contact / Rated value	A	10
Insulation voltage / of the auxiliary switch / Rated	V	500
value		
Suitability		
Suitability for use		
Main switch		Yes
 switch disconnector 		Yes
 EMERGENCY OFF switch 		No
safety switch		Yes
 maintenance/repair switch 		Yes
Product details		
Product feature / interlock		Yes
Product expansion / optional		
• motor drive		No
 Voltage trigger 		No
Connections		
Connectable conductor cross-section		
• for main contacts		
— single or multi-stranded / minimum	mm²	4
— single or multi-stranded / maximum	mm²	50
finely stranded / with core end processing / maximum	mm²	35
— stranded / minimum	mm²	4
— stranded / maximum	mm²	50
• for auxiliary contacts		
•		

		0.75
— single or multi-stranded / minimum	mm²	0.75
— single or multi-stranded / maximum	mm²	4
— finely stranded / with core end processing / minimum	mm²	0.75
finely stranded / with core end processing / maximum	mm²	2.5
— stranded / minimum	mm²	0.75
— stranded / maximum	mm²	4
Type of connectable conductor cross-section		
• for main contacts / finely stranded / with core		35
end processing		
for auxiliary contacts		
— solid		50
— finely stranded / with core end processing		2x (0.75 1.5 mm2), 1x 2.5 mm2
Type of electrical connection		
• for main current circuit		connection terminals
• for auxiliary contacts		connection terminals
D		
Requirements Design of the fuse link		
• for short-circuit protection of the main circuit /		fuse gL/gG: 125 A
required		
 for short-circuit protection of the auxiliary switch / required 		fuse gL/gG: 10 A
Mechanical Design		
Height	mm	83
Helgitt		
Width	mm	71
Width	mm mm	71 97
Width		
Width		97
Width Depth Mounting type		97
Width Depth Mounting type Mounting type		97 floor mounting
Width Depth Mounting type Mounting type • front mounting		97 floor mounting No
Width Depth Mounting type Mounting type • front mounting • front mounting with 4-hole attachment		97 floor mounting No No
Width Depth Mounting type Mounting type • front mounting • front mounting with 4-hole attachment • front mounting with central attachment		97 floor mounting No No No
Width Depth Mounting type Mounting type • front mounting • front mounting with 4-hole attachment • front mounting with central attachment • Side-by-side mounting • rail mounting Environmental conditions		97 floor mounting No No No Yes
Width Depth Mounting type Mounting type • front mounting • front mounting with 4-hole attachment • front mounting with central attachment • Side-by-side mounting • rail mounting Environmental conditions Ambient temperature	mm	97 floor mounting No No No Yes No
Width Depth Mounting type Mounting type • front mounting • front mounting with 4-hole attachment • front mounting with central attachment • Side-by-side mounting • rail mounting Environmental conditions	mm	97 floor mounting No No No Yes No
Width Depth Mounting type Mounting type • front mounting • front mounting with 4-hole attachment • front mounting with central attachment • Side-by-side mounting • rail mounting Environmental conditions Ambient temperature	mm	97 floor mounting No No No Yes No
Width Depth Mounting type • front mounting • front mounting with 4-hole attachment • front mounting with central attachment • Side-by-side mounting • rail mounting Environmental conditions Ambient temperature • during operation / minimum • during operation / maximum Certificates	mm	97 floor mounting No No No Yes No
Width Depth Mounting type • front mounting • front mounting with 4-hole attachment • front mounting with central attachment • Side-by-side mounting • rail mounting Environmental conditions Ambient temperature • during operation / minimum • during operation / maximum	mm	97 floor mounting No No No Yes No

General Product Approval









GL





General Product Approval	Declaration of Conformity	Test Certificates	Shipping Approval	other
other	ϵ	Special Test Certificate	GL®	Environmental Confirmations

Further information

Information- and Downloadcenter (Catalogs, Brochures,...)

EG-Konf.

http://www.siemens.com/lowvoltage/catalogs

Industry Mall (Online ordering system)

https://eb.automation.siemens.com/mall/en/WW/Catalog/Product/3LD28300TK11

Service&Support (Manuals, Certificates, Characteristics, FAQs,...) http://support.automation.siemens.com/WW/view/en/3LD28300TK11/all

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)


http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3LD28300TK11

CAx-Online-Generator

http://www.siemens.com/cax

Tender specifications

http://ausschreibungstexte.siemens.com/tiplv



last modified: 11.03.2015