

CERTIFICATE OF COMPLIANCE

Certificate Number 20180607-E203225
Report Reference E203225-20180606
Issue Date 2018-JUNE-07

Issued to: HMS Industrial Networks AB
STATIONSGATAN 37
SE-30245 HALMSTAD SWEDEN

**This is to certify that
representative samples of**

PROGRAMMABLE CONTROLLERS FOR USE IN
HAZARDOUS LOCATIONS

AWB2, followed by additional suffixes numbers or letters,
for use in Class I, Division 2, Groups A, B, C and D
Hazardous Locations.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:


Standard No. UL 121201 and CAN/CSA C22.2 NO. 213,
NONINCENDIVE ELECTRICAL EQUIPMENT FOR USE IN
CLASS I AND II, DIVISION 2 AND CLASS III, DIVISIONS 1 AND
2 HAZARDOUS (CLASSIFIED) LOCATIONS

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

