## **SIEMENS**

Data sheet 7PV1538-1AW30



TIME RELAY, SOLID STATE, OFF-DELAY, WITH AUXILIARY VOLTAGE, 1 CHANGEOVER CONT. 7 TIME RANGES, 0.05S...100H, 12...240V AC/DC, WITH LED, SCREW CONNECTION

General technical data:		
product brand name		SIRIUS
Product designation		timing relay
Adjustable time	S	0.05 360 000
Protection class IP		
• on the front		IP40
• of the terminal		IP20
Shock resistance		15g / 11 ms
Degree of pollution		2
mounting position		any
Supply voltage required Auxiliary voltage		Yes
Product function		
• star-delta circuit		No
<ul><li>with auxiliary voltage pulse-shaping</li></ul>		No
<ul> <li>at the relay outputs Switchover delayed/without delay</li> </ul>		No
Product component semi-conductor output		No
Product expansion		
<ul> <li>optional remote control</li> </ul>		No
<ul> <li>required remote control</li> </ul>		No
Installation altitude at height above sea level	m	2 000
maximum		
Ambient temperature		
during storage	°C	-40 <b>+</b> 70
<ul> <li>during operation</li> </ul>	°C	-25 <b>+</b> 55

during transport	°C	-40 <b>+7</b> 0
Relative humidity during operation	%	15 85
EMI immunity acc. to IEC 60947-1		corresponds to degree of severity 3
EMC emitted interference acc. to IEC 60947-1		IEC61000-6-3 (residential area)
Conducted interference due to burst acc. to IEC 61000-4-4		2 kV network connection / 1 kV control connection
Conducted interference due to conductor-earth surge acc. to IEC 61000-4-5		2 kV
Conducted interference due to conductor-conductor surge acc. to IEC 61000-4-5		1 kV
Electrostatic discharge acc. to IEC 61000-4-2		4 kV contact discharge / 8 kV air discharge
Field-bound parasitic coupling acc. to IEC 61000-4-3		10 V/m
Vibration resistance		10 55 Hz / 0.35 mm
Surge voltage resistance Rated value	V	4 000
Insulation voltage Rated value	V	300
Active power loss total typical	W	2
Equipment marking acc. to DIN 40719 extended according to IEC 204-2 acc. to IEC 750		К
Equipment marking acc. to DIN EN 61346-2		К

Switching Function:	
Switching function	
<ul> <li>passing make contact</li> </ul>	No
<ul> <li>fixed clock cycle beginning with pulse</li> </ul>	No
<ul> <li>variably clocked start with interval</li> </ul>	No
OFF delay	No
<ul> <li>variably clocked start with impulse</li> </ul>	No
<ul><li>with control signal</li></ul>	
<ul> <li>passing break contact</li> </ul>	No
— OFF delay	Yes
— additive ON delay	No
<ul> <li>passing break contact/instantaneous</li> </ul>	No
<ul> <li>OFF delay/instantaneous</li> </ul>	No
<ul><li>— ON-delay/OFF-delay/instantaneous</li></ul>	No
<ul><li>pulse-shaping/instantaneous</li></ul>	No
— pulse-shaping	No
<ul> <li>ON-delay/instantaneous contact</li> </ul>	No
<ul> <li>ON-delay/instantaneous contact</li> </ul>	No
• passing make contact/instantaneous contact	No
<ul> <li>fixed clock cycle beginning with interval</li> </ul>	No
<ul> <li>without control signal OFF delay</li> </ul>	No
ON-delay	No

• fixed clock cycle beginning with		No
interval/instantaneous contact		
Control circuit/ Control:		
Type of voltage of the control supply voltage		AC/DC
Control supply voltage frequency 1	Hz	50 60
Control supply voltage 1		
• with AC		
— at 50 Hz	V	12 240
— at 60 Hz	V	12 240
• for DC	V	12 240
Operating range factor control supply voltage rated value of the magnet coil		0.85 1.1
Auxiliary circuit:		
Operating current of the auxiliary contacts		
• at AC-15		
— at 24 V	Α	3
— at 250 V	Α	3
• at DC-13		
— at 24 V	Α	1
— at 125 V	Α	0.22
— at 250 V	Α	0.1
— maximum	Α	1
Number of NC contacts		
<ul><li>delayed switching</li></ul>		0
• instantaneous contact		0
Number of NO contacts		
<ul><li>delayed switching</li></ul>		0
• instantaneous contact		0
Number of CO contacts		
<ul><li>delayed switching</li></ul>		1
• instantaneous contact		0
Short-circuit:		
Design of the fuse link for short-circuit protection of		fuse gL/gG: 4 A
the auxiliary switch required		
Installation/ mounting/ dimensions:		
Mounting type		snap-on fastening on 35 mm standard rail
Width	mm	17.5
Height	mm	90
Depth	mm	66.7
Required spacing		
<ul><li>with side-by-side mounting</li></ul>		

— upwards	mm	0
— downwards	mm	0
— forwards	mm	0
— Backwards	mm	0
— at the side	mm	0
• for grounded parts		
— upwards	mm	0
— downwards	mm	0
— forwards	mm	0
— Backwards	mm	0
— at the side	mm	0
• for live parts		
— upwards	mm	0
— downwards	mm	0
— forwards	mm	0
— Backwards	mm	0
— at the side	mm	0

Connections/ Terminals:		
Type of electrical connection		
<ul> <li>Plug-in socket</li> </ul>		No
<ul> <li>for auxiliary and control current circuit</li> </ul>		screw-type terminals
Type of connectable conductor cross-section		
for auxiliary contacts		
— solid		1x (0.2 2.5 mm²)
— finely stranded		
<ul> <li>— with core end processing</li> </ul>		0.25 1.5 mm <sup>2</sup>
<ul> <li>— without core end processing</li> </ul>		1x (0.2 1.5 mm²)
<ul> <li>for AWG conductors for auxiliary contacts</li> </ul>		1x (24 14)
Connectable conductor cross-section for auxiliary		
contacts		
<ul> <li>single or multi-stranded</li> </ul>	mm²	0.2 2.5
• finely stranded		
<ul><li>— with core end processing</li></ul>	mm²	0.25 1.5
<ul> <li>without core end processing</li> </ul>	mm²	0.2 1.5
AWG number as coded connectable conductor cross section for auxiliary contacts		14 24

Certificates/ approvals:		
Certificate of suitability	CE	

## **General Product Approval**

## **Declaration of Conformity**







CCC

Safety related data:	
Category acc. to EN 954-1	none
Protection against electrical shock	finger-safe

## Further information

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/industrial-controls/catalogs

Industry Mall (Online ordering system)

http://www.siemens.com/industrymall


Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=7PV15381AW30


Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/7PV15381AW30

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...) http://www.automation.siemens.com/bilddb/cax\_de.aspx?mlfb=7PV15381AW30&lang=en







**last modified:** 16.03.2015

TIME RELAY, OFF-DELAY, I CHANGE-OVER CONTACT